



ENERGY DIRECTORATE

TYPE TESTED INVERTERS/EQUIPMENT IN TERMS OF NRS 097-2-1

2023/07/26

Make	Model	Inverter / Equipment type	Test House	Certificate date	Certificate valid until	Report number	Certificate Compliance number	NRS 097-2-1: 2017 Ed2 Certification	NRS 097-2-1: 2017 Ed 2.1 Certification	Comments
ABB	TRIO-TM-50.0-400	Grid-tied PV inverter	TUV Rheinland	2019/07/15		28110633 031	AK 60141064 0001	Yes		Inverter may only be used in plants according to Category A3: 100 kVA - 1MVA and connection to the grid via an external customer MV/LV AC transformer.
ABB	PVS - 50 - TL	Grid-tied PV inverter	TUV Rheinland	2020/01/22		28111830 029	AK 60146346 0001	Yes		
ABB	PVS - 50 - TL - S	Grid-tied PV inverter	TUV Rheinland	2020/01/22		28111830 029	AK 60146346 0001	Yes		
ABB	PVS - 50 - TL - SX	Grid-tied PV inverter	TUV Rheinland	2020/01/22		28111830 029	AK 60146346 0001	Yes		
ABB	PVS - 50 - TL - SX2	Grid-tied PV inverter	TUV Rheinland	2020/01/22		28111830 029	AK 60146346 0001	Yes		Inverter may only be used in plants according to Category A3: 100 kVA - 1MVA and connection to the grid via an external customer MV/LV AC transformer.
ABB	PVS-100-TL	Grid-tied PV inverter	TUV Rheinland	2019/11/29		28110923 035	AK 60144898 0001	Yes		
ABB	REACT2-UNO-3.6-TL	Grid-tied PV inverter	TUV Rheinland	2018/11/07		28111587 003	AK 60134062 0001	Yes		
ABB	REACT2-UNO-5.0-TL	Grid-tied PV inverter	TUV Rheinland	2018/11/07		28111587 003	AK 60134062 0001	Yes		
ABB	CM-UF0 M31M and CM-UF0 M31	Network & system relay	TUV SÜD	2022/10/28		713200958-000	ESY 0442540043 Rev.00	No	No	Network and system grid protection voltage and frequency relay only in accordance with VDE-AR-N 4105:2018. Must be programmed to NRS 097-2-1 or the applicable South African Grid Codes and may only be used in conjunction with approved NRS 097-2-1 type tested inverters on this list.
Afore	HNS3000HS	Hybrid PV inverter grid-tied	Dekra	2020/09/17		6076139 50	6076139.01AOC	Yes	Yes	
Afore	HNS3600HS	Hybrid PV inverter grid-tied	Dekra	2020/09/17		6076139 50	6076139.01AOC	Yes	Yes	
Afore	HNS4000HS	Hybrid PV inverter grid-tied	Dekra	2020/09/17		6076139 50	6076139.01AOC	Yes	Yes	
Afore	HNS4600HS	Hybrid PV inverter grid-tied	Dekra	2020/09/17		6076139 50	6076139.01AOC	Yes	Yes	
Afore	HNS5000HS	Hybrid PV inverter grid-tied	Dekra	2020/09/17		6076139 50	6076139.01AOC	Yes	Yes	
Afore	HNS5500HS	Hybrid PV inverter grid-tied	Dekra	2020/09/17		6076139 50	6076139.01AOC	Yes	Yes	
Afore	HNS6000HS	Hybrid PV inverter grid-tied	Dekra	2020/09/17		6076139 50	6076139.01AOC	Yes	Yes	
Afore	HNS3000HS-HV	Hybrid PV inverter grid-tied	Dekra	2020/09/18		6076141 50	6076141.01AOC V1.1	Yes	Yes	
Afore	HNS3600HS-HV	Hybrid PV inverter grid-tied	Dekra	2020/09/18		6076141 50	6076141.01AOC V1.1	Yes	Yes	
Afore	HNS4000HS-HV	Hybrid PV inverter grid-tied	Dekra	2020/09/18		6076141 50	6076141.01AOC V1.1	Yes	Yes	
Afore	HNS4600HS-HV	Hybrid PV inverter grid-tied	Dekra	2020/09/18		6076141 50	6076141.01AOC V1.1	Yes	Yes	
Afore	HNS5000HS-HV	Hybrid PV inverter grid-tied	Dekra	2020/09/18		6076141 50	6076141.01AOC V1.1	Yes	Yes	
Afore	HNS5500HS-HV	Hybrid PV inverter grid-tied	Dekra	2020/09/18		6076141 50	6076141.01AOC V1.1	Yes	Yes	
Afore	HNS6000HS-HV	Hybrid PV inverter grid-tied	Dekra	2020/09/18		6076141 50	6076141.01AOC V1.1	Yes	Yes	
Afore	AF3K-SL	Hybrid PV inverter grid-tied	Dekra	2021/03/10		6098057 50	6098057.01AOC	Yes	Yes	
Afore	AF3.6K-SL	Hybrid PV inverter grid-tied	Dekra	2021/03/10		6098057 50	6098057.01AOC	Yes	Yes	
Afore	AF4K-SL	Hybrid PV inverter grid-tied	Dekra	2021/03/10		6098057 50	6098057.01AOC	Yes	Yes	
Afore	AF4.6K-SL	Hybrid PV inverter grid-tied	Dekra	2021/03/10		6098057 50	6098057.01AOC	Yes	Yes	
Afore	AF5K-SL	Hybrid PV inverter grid-tied	Dekra	2021/03/10		6098057 50	6098057.01AOC	Yes	Yes	
Afore	AF6K-SL	Hybrid PV inverter grid-tied	Dekra	2021/03/10		6098057 50	6098057.01AOC	Yes	Yes	
Afore	AF3K-TH	Hybrid PV inverter grid-tied	Intertek	2023/05/25		230500127SHA-001	CN-PV-230262	Yes	Yes	
Afore	AF4K-TH	Hybrid PV inverter grid-tied	Intertek	2023/05/25		230500127SHA-001	CN-PV-230262	Yes	Yes	
Afore	AF5K-TH	Hybrid PV inverter grid-tied	Intertek	2023/05/25		230500127SHA-001	CN-PV-230262	Yes	Yes	
Afore	AF6K-TH	Hybrid PV inverter grid-tied	Intertek	2023/05/25		230500127SHA-001	CN-PV-230262	Yes	Yes	
Afore	AF8K-TH	Hybrid PV inverter grid-tied	Intertek	2023/05/25		230500127SHA-001	CN-PV-230262	Yes	Yes	
Afore	AF10K-TH	Hybrid PV inverter grid-tied	Intertek	2023/05/25		230500127SHA-001	CN-PV-230262	Yes	Yes	
Afore	AF12K-TH	Hybrid PV inverter grid-tied	Intertek	2023/05/25		230500127SHA-001	CN-PV-230262	Yes	Yes	
Afore	AF15K-TH	Hybrid PV inverter grid-tied	Intertek	2023/05/25		230500127SHA-001	CN-PV-230262	Yes	Yes	
Afore	AF17K-TH	Hybrid PV inverter grid-tied	Intertek	2023/05/25		230500127SHA-001	CN-PV-230262	Yes	Yes	
Afore	AF20K-TH	Hybrid PV inverter grid-tied	Intertek	2023/05/25		230500127SHA-001	CN-PV-230262	Yes	Yes	
Afore	AF25K-TH	Hybrid PV inverter grid-tied	Intertek	2023/05/25		230500127SHA-001	CN-PV-230262	Yes	Yes	
Afore	AF30K-TH	Hybrid PV inverter grid-tied	Intertek	2023/05/25		230500127SHA-001	CN-PV-230262	Yes	Yes	
Afore	AF3K-THP	Hybrid PV inverter grid-tied	Intertek	2023/05/25		230500127SHA-001	CN-PV-230262	Yes	Yes	
Afore	AF4K-THP	Hybrid PV inverter grid-tied	Intertek	2023/05/25		230500127SHA-001	CN-PV-230262	Yes	Yes	
Afore	AF5K-THP	Hybrid PV inverter grid-tied	Intertek	2023/05/25		230500127SHA-001	CN-PV-230262	Yes	Yes	
Afore	AF6K-THP	Hybrid PV inverter grid-tied	Intertek	2023/05/25		230500127SHA-001	CN-PV-230262	Yes	Yes	
Afore	AF8K-THP	Hybrid PV inverter grid-tied	Intertek	2023/05/25		230500127SHA-001	CN-PV-230262	Yes	Yes	
Afore	AF10K-THP	Hybrid PV inverter grid-tied	Intertek	2023/05/25		230500127SHA-001	CN-PV-230262	Yes	Yes	
Afore	AF12K-THP	Hybrid PV inverter grid-tied	Intertek	2023/05/25		230500127SHA-001	CN-PV-230262	Yes	Yes	
Atess	HPS 30	Hybrid PV inverter grid-tied	Shenzhen Balun	2020/10/09		BL-DG2080269-B01	BL-DG2080269D01	Yes	Yes	The maximum DC voltage is depended on PV array and may not exceed 820 V as declared by the inverter manufacturer.
Atess	HPS 50	Hybrid PV inverter grid-tied	Shenzhen Balun	2020/10/09		BL-DG2080269-B01	BL-DG2080269D01	Yes	Yes	The maximum DC voltage is depended on PV array and may not exceed 820 V as declared by the inverter manufacturer.
Atess	HPS100	Hybrid PV inverter grid-tied	Shenzhen Balun	2020/10/09		BL-DG2080269-B02	BL-DG2080269D02	Yes	Yes	The maximum DC voltage is depended on PV array and may not exceed 820 V as declared by the inverter manufacturer.
Atess	HPS120	Hybrid PV inverter grid-tied	Shenzhen Balun	2020/10/09		BL-DG2080269-B02	BL-DG2080269D02	Yes	Yes	The maximum DC voltage is depended on PV array and may not exceed 820 V as declared by the inverter manufacturer.
Atess	HPS150	Hybrid PV inverter grid-tied	Shenzhen Balun	2020/10/09		BL-DG2080269-B02	BL-DG2080269D02	Yes	Yes	The maximum DC voltage is depended on PV array and may not exceed 820 V as declared by the inverter manufacturer.
Alpha	SMILE5-INV	Bureau Veritas	Bureau Veritas	2019/03/22		ABYD-19JA1440FCSHP	U19-0178	Yes	Yes	
Alpha	Storion-SMILE-B3	Battery based inverter grid-tied	Bureau Veritas	2020/08/19		ABYD-ESH-P20071636	U20-0680	Yes	Yes	
Blue Mountain Energy	BME-3P-WP-12 TWIN	Hybrid PV inverter grid-tied	Huachuang Technology	2023/03/20		23110JHA009-EG-ZA-002	23110JHA009-EG-ZA-C002	Yes	Yes	
Blue Mountain Energy	BME-3P-WP-15 TWIN	Hybrid PV inverter grid-tied	Huachuang Technology	2023/03/20		23110JHA009-EG-ZA-002	23110JHA009-EG-ZA-C002	Yes	Yes	
Bluesun	BSE6KH3	Hybrid PV inverter grid-tied	TUV SÜD	2023/03/24		64 290 23.30183.01	D 093536 0019 Rev.00	Yes	Yes	
Bluesun	BSE8KH3	Hybrid PV inverter grid-tied	TUV SÜD	2023/03/24		64 290 23.30183.01	D 093536 0019 Rev.00	Yes	Yes	
Bluesun	BSE10KH3	Hybrid PV inverter grid-tied	TUV SÜD	2023/03/24		64 290 23.30183.01	D 093536 0019 Rev.00	Yes	Yes	
Bluesun	BSE12KH3	Hybrid PV inverter grid-tied	TUV SÜD	2023/03/24		64 290 23.30183.01	D 093536 0019 Rev.00	Yes	Yes	
Bluesun	BSE15KH3	Hybrid PV inverter grid-tied	TUV SÜD	2023/03/24		64 290 23.30183.01	D 093536 0019 Rev.00	Yes	Yes	
Canadian Solar	CSI-20, 25 and 30KTL-GI-FL	Grid-tied PV inverter	TUV Rheinland	2018/05/07		50128276 002	AK 50406933 0001	Yes	Yes	
Canadian Solar	CSI-40KTL-GI-FL	Grid-tied PV inverter	TUV Rheinland	2018/05/03		50131287 002	AK 50406675 0001	Yes	Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Canadian Solar	CSI-50KTL-GI-FL	Grid-tied PV inverter	TUV Rheinland	2018/05/03		50131287 002	AK 50406675 0001	Yes	Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Canadian Solar	CSI-25K-T400GL02-E	Grid-tied PV inverter	TUV Rheinland	2020/04/13		50344275 002	AK 50464349 0001	Yes	Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.

[illegible]

Fronius	TAURO ECO 100-3-D	Grid-tied PV inverter	TUV Rheinland	2022/01/25	IT2227D0 001	AK 60161549 0001		Yes	inverter may only be used in plants according to category A.3. 100 kVA - 1MVA and connection to the grid via an external customer MV/LV AC transformer.
Fronius	TAURO 50-3-P	Grid-tied PV inverter	TUV Rheinland	2022/01/27	IT221Y5I 001	AK 60161577 0001		Yes	inverter may only be used in plants according to category A.3. 100 kVA - 1MVA and connection to the grid via an external customer MV/LV AC transformer.
Fronius	TAURO 50-3-D	Grid-tied PV inverter	TUV Rheinland	2022/01/27	IT221Y5I 001	AK 60161577 0001		Yes	inverter may only be used in plants according to category A.3. 100 kVA - 1MVA and connection to the grid via an external customer MV/LV AC transformer.
Goodwe	GW3648D-ES	Hybrid PV inverter grid-tied	TUV SÜD	2018/11/12	704091815302-00	D 083373 0039 Rev.00	Yes		
Goodwe	GW5048D-ES	Hybrid PV inverter grid-tied	TUV SÜD	2018/11/12	704091815302-00	D 083373 0039 Rev.00	Yes		
Goodwe	GW3048-EM	Hybrid PV inverter grid-tied	TUV Rheinland	2017/07/14	50085060 001	AK 50383738 0001	Yes		
Goodwe	GW3648-EM	Hybrid PV inverter grid-tied	TUV Rheinland	2017/07/14	50085060 001	AK 50383738 0001	Yes		
Goodwe	GW5048-EM	Hybrid PV inverter grid-tied	TUV Rheinland	2017/07/14	50085060 001	AK 50383738 0001	Yes		
Goodwe	GW4K-DT	Grid-tied PV inverter	Bureau Veritas	2019/11/20	ZEM-190C0893FTSHP	U19-0609	Yes		
Goodwe	GW5K-DT	Grid-tied PV inverter	Bureau Veritas	2019/11/20	ZEM-190C0893FTSHP	U19-0609	Yes		
Goodwe	GW6K-DT	Grid-tied PV inverter	Bureau Veritas	2019/11/20	ZEM-190C0893FTSHP	U19-0609	Yes		
Goodwe	GW8K-DT	Grid-tied PV inverter	Bureau Veritas	2019/11/20	ZEM-190C0893FTSHP	U19-0609	Yes		
Goodwe	GW10KT-DT	Grid-tied PV inverter	Bureau Veritas	2019/11/20	ZEM-190C0893FTSHP	U19-0609	Yes		
Goodwe	GW12KT-DT	Grid-tied PV inverter	Bureau Veritas	2019/11/20	ZEM-190C0893FTSHP	U19-0609	Yes		
Goodwe	GW15KT-DT	Grid-tied PV inverter	Bureau Veritas	2019/11/20	ZEM-190C0893FTSHP	U19-0609	Yes		
Goodwe	GW500S-BP	Battery based inverter grid-tied	TUV Rheinland	2018/11/12	50180648 001	AK 50419930 0001	Yes		
Goodwe	GW360S-BP	Battery based inverter grid-tied	TUV Rheinland	2018/11/12	50180648 001	AK 50419930 0001	Yes		
Goodwe	GW5K-ET	Hybrid PV inverter grid-tied	Bureau Veritas	2019/05/23	PVZA190507N014	1988AP0507N014001	Yes		
Goodwe	GW8K-ET	Hybrid PV inverter grid-tied	Bureau Veritas	2019/05/23	PVZA190507N014	1988AP0507N014001	Yes		
Goodwe	GW10K-ET	Hybrid PV inverter grid-tied	Bureau Veritas	2019/05/23	PVZA190507N014	1988AP0507N014001	Yes		
Goodwe	GW25K-MT	Grid-tied PV inverter	Bureau Veritas	2020/03/05	PVZA181008N021-R1	1888AP1008N021015	Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Goodwe	GW30K-MT	Grid-tied PV inverter	Bureau Veritas	2020/03/05	PVZA181008N021-R1	1888AP1008N021015	Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Goodwe	GW36K-MT	Grid-tied PV inverter	Bureau Veritas	2020/03/05	PVZA181008N021-R1	1888AP1008N021015	Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Goodwe	GW50K-MT	Grid-tied PV inverter	Bureau Veritas	2022/05/06	PVZA180903N057-R2	1888AP0903N057004	Yes	Yes	
Goodwe	GW60K-MT	Grid-tied PV inverter	Bureau Veritas	2022/05/06	PVZA180903N057-R2	1888AP0903N057004	Yes	Yes	
Goodwe	GW50KN-MT	Grid-tied PV inverter	Bureau Veritas	2022/05/06	PVZA180903N057-R2	1888AP0903N057004	Yes	Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Goodwe	GW60KN-MT	Grid-tied PV inverter	Bureau Veritas	2022/05/06	PVZA180903N057-R2	1888AP0903N057004	Yes	Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Goodwe	GW 3000D-NS	Grid-tied PV inverter	Bureau Veritas	2020/01/19	PVZA190627N029	1988AP0627N0290001	Yes		
Goodwe	GW 3600D-NS	Grid-tied PV inverter	Bureau Veritas	2020/01/19	PVZA190627N029	1988AP0627N0290001	Yes		
Goodwe	GW 4200D-NS	Grid-tied PV inverter	Bureau Veritas	2020/01/19	PVZA190627N029	1988AP0627N0290001	Yes		
Goodwe	GW 5000D-NS	Grid-tied PV inverter	Bureau Veritas	2020/01/19	PVZA190627N029	1988AP0627N0290001	Yes		
Goodwe	GW 6000D-NS	Grid-tied PV inverter	Bureau Veritas	2020/01/19	PVZA190627N029	1988AP0627N0290001	Yes		
Goodwe	GW 20KN-DT	Grid-tied PV inverter	Bureau Veritas	2020/04/17	ASBJ-190C2322FTSHS	U20-0270	Yes		
Goodwe	GW 17KN-DT	Grid-tied PV inverter	Bureau Veritas	2020/04/17	ASBJ-190C2322FTSHS	U20-0270	Yes		
Goodwe	GW 15KN-DT	Grid-tied PV inverter	Bureau Veritas	2020/04/17	ASBJ-190C2322FTSHS	U20-0270	Yes		
Goodwe	GW 12KN-DT	Grid-tied PV inverter	Bureau Veritas	2020/04/17	ASBJ-190C2322FTSHS	U20-0270	Yes		
Goodwe	GW 100K-HT	Grid-tied PV inverter	TUV Rheinland	2020/12/24	CN20W6U3 001	AK 50490607 0001	Yes	Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Goodwe	GW 110K-HT	Grid-tied PV inverter	TUV Rheinland	2020/12/24	CN20W6U3 001	AK 50490607 0001	Yes	Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Goodwe	GW 120K-HT	Grid-tied PV inverter	TUV Rheinland	2020/12/24	CN20W6U3 001	AK 50490607 0001	Yes	Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Goodwe	GW 136K-HTH	Grid-tied PV inverter	TUV Rheinland	2020/12/24	CN20W6U3 001	AK 50490607 0001	Yes	Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Goodwe	GW5000-EHB	Hybrid PV inverter grid-tied	SGS	2021/11/11	2220/0404-E1	2620/0404-E1-CER	Yes	Yes	
Goodwe	GW6500-EHB	Hybrid PV inverter grid-tied	SGS	2021/11/11	2220/0404-E1	2620/0404-E1-CER	Yes	Yes	
Goodwe	GW8600-EHB	Hybrid PV inverter grid-tied	SGS	2021/11/11	2220/0404-E1	2620/0404-E1-CER	Yes	Yes	
Goodwe	GW0010-EHB	Hybrid PV inverter grid-tied	SGS	2021/11/11	2220/0404-E1	2620/0404-E1-CER	Yes	Yes	
Goodwe	GW 17KT-DT	Hybrid PV inverter grid-tied	TUV Rheinland	2022/04/15	60395681 002	AK 50540008 0001	Yes	Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Goodwe	GW 20KT-DT	Hybrid PV inverter grid-tied	TUV Rheinland	2022/04/15	60395681 002	AK 50540008 0001	Yes	Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Goodwe	GW 25KT-DT	Hybrid PV inverter grid-tied	TUV Rheinland	2022/04/15	60395681 002	AK 50540008 0001	Yes	Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Goodwe	GW50KS-MT	Grid-tied PV inverter	TUV NORD & Donguan Balun	2022/06/07	TRPVP11058/21E/02	COCPPV11058/21E-04	Yes	Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Goodwe	GW60KS-MT	Grid-tied PV inverter	TUV NORD & Donguan Balun	2022/06/07	TRPVP11058/21E/02	COCPPV11058/21E-04	Yes	Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Goodwe	GWx-ES-20	Hybrid PV inverter grid-tied	TUV Rheinland	2022/07/06	CN22SCQU 001	AK 50550767 0001	Yes	Yes	Where x = 3600, 3600, 5000, 6000
Goodwe	GWx-ES-20	Hybrid PV inverter grid-tied	TUV Rheinland	2022/07/06	CN22SCQU 001	AK 50550767 0001	Yes	Yes	Where x = 3600, 3600, 5000, 6000
Goodwe	GWx-SBP-20	Hybrid PV inverter grid-tied	TUV Rheinland	2022/07/06	CN22SCQU 001	AK 50550767 0001	Yes	Yes	Where x = 3600, 3600, 5000, 6000
Goodwe	GW80K-MT	Grid-tied PV inverter	Bureau Veritas	2022/08/10	PVZA191217N016-R2	2288AP080035001	Yes	Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Goodwe	GW15K-ET	Hybrid PV inverter grid-tied	TUV Rheinland	2023/05/06	CN23Y4NN 001	AK 50583164 0001	Yes	Yes	
Goodwe	GW20K-ET	Hybrid PV inverter grid-tied	TUV Rheinland	2023/05/06	CN23Y4NN 001	AK 50583164 0001	Yes	Yes	
Goodwe	GW25K-ET	Hybrid PV inverter grid-tied	TUV Rheinland	2023/05/06	CN23Y4NN 001	AK 50583164 0001	Yes	Yes	
Goodwe	GW29 9K-ET	Hybrid PV inverter grid-tied	TUV Rheinland	2023/05/06	CN23Y4NN 001	AK 50583164 0001	Yes	Yes	
Goodwe	GW30K-ET	Hybrid PV inverter grid-tied	TUV Rheinland	2023/05/06	CN23Y4NN 001	AK 50583164 0001	Yes	Yes	
Growatt	SPH3000TL BL-UP	Hybrid PV inverter grid-tied	Intertek	2019/10/25	190719102GZU-001	CN-PV-190037	Yes		
Growatt	SPH3600TL BL-UP	Hybrid PV inverter grid-tied	Intertek	2019/10/25	190719102GZU-001	CN-PV-190037	Yes		
Growatt	SPH4000TL BL-UP	Hybrid PV inverter grid-tied	Intertek	2019/10/25	190719102GZU-001	CN-PV-190037	Yes		
Growatt	SPH4600TL BL-UP	Hybrid PV inverter grid-tied	Intertek	2019/10/25	190719102GZU-001	CN-PV-190037	Yes		
Growatt	SPH5000TL BL-UP	Hybrid PV inverter grid-tied	Intertek	2019/10/25	190719102GZU-001	CN-PV-190037	Yes		
Growatt	SPH6000TL BL-UP	Hybrid PV inverter grid-tied	Intertek	2019/10/25	190719102GZU-001	CN-PV-190037	Yes		
Growcol	GHyper-3000	Hybrid PV inverter grid-tied	Dekra	2021/08/20	6111798 51	6111798 02AAC	Yes	Yes	
Growcol	GHyper-3680	Hybrid PV inverter grid-tied	Dekra	2021/08/20	6111798 51	6111798 02AAC	Yes	Yes	
Growcol	GHyper-5000	Hybrid PV inverter grid-tied	Dekra	2021/08/20	6111798 51	6111798 02AAC	Yes	Yes	
Growcol	GX25KT	Grid-tied PV inverter	Intertek	2022/06/27	220120058GZU-001, Rev 1	CN-PV-220040R1	Yes	Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growcol	GX25KT-S	Grid-tied PV inverter	Intertek	2022/06/27	220120058GZU-001, Rev 1	CN-PV-220040R1	Yes	Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growcol	GX30KT	Grid-tied PV inverter	Intertek	2022/06/27	220120058GZU-001, Rev 1	CN-PV-220040R1	Yes	Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growcol	GX30KT-S	Grid-tied PV inverter	Intertek	2022/06/27	220120058GZU-001, Rev 1	CN-PV-220040R1	Yes	Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growcol	GX33KT	Grid-tied PV inverter	Intertek	2022/06/27	220120058GZU-001, Rev 1	CN-PV-220040R1	Yes	Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growcol	GX33KT-S	Grid-tied PV inverter	Intertek	2022/06/27	220120058GZU-001, Rev 1	CN-PV-220040R1	Yes	Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growcol	GX38KT	Grid-tied PV inverter	Intertek	2022/06/27	220120058GZU-001, Rev 1	CN-PV-220040R1	Yes	Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.

Growco	GX36KT-S	Grid-tied PV inverter	Intertek	2022/06/27		220120058GZU-001, Rev 1	CN-PV-220040R1		Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growco	GX40KT	Grid-tied PV inverter	Intertek	2022/06/27		220120058GZU-001, Rev 1	CN-PV-220040R1		Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growco	GX40KT-S	Grid-tied PV inverter	Intertek	2022/06/27		220120058GZU-001, Rev 1	CN-PV-220040R1		Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growco	GX50KT	Grid-tied PV inverter	Intertek	2022/06/27		220120057GZU-001, Rev 1	CN-PV-220039R1		Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growco	GX50KTL	Grid-tied PV inverter	Intertek	2022/06/27		220120057GZU-001, Rev 1	CN-PV-220039R1		Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growco	GX50KTL-S	Grid-tied PV inverter	Intertek	2022/06/27		220120057GZU-001, Rev 1	CN-PV-220039R1		Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growco	GX50KT-S	Grid-tied PV inverter	Intertek	2022/06/27		220120057GZU-001, Rev 1	CN-PV-220039R1		Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growco	GX60KT	Grid-tied PV inverter	Intertek	2022/06/27		220120057GZU-001, Rev 1	CN-PV-220039R1		Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growco	GX60KTL	Grid-tied PV inverter	Intertek	2022/06/27		220120057GZU-001, Rev 1	CN-PV-220039R1		Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growco	GX60KTL-S	Grid-tied PV inverter	Intertek	2022/06/27		220120057GZU-001, Rev 1	CN-PV-220039R1		Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growco	GX60KT-S	Grid-tied PV inverter	Intertek	2022/06/27		220120057GZU-001, Rev 1	CN-PV-220039R1		Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growco	GX66KT	Grid-tied PV inverter	Intertek	2022/06/27		220120057GZU-001, Rev 1	CN-PV-220039R1		Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growco	GX66KT-S	Grid-tied PV inverter	Intertek	2022/06/27		220120057GZU-001, Rev 1	CN-PV-220039R1		Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growco	GX70KT	Grid-tied PV inverter	Intertek	2022/06/27		220120057GZU-001, Rev 1	CN-PV-220039R1		Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growco	GX70KT-S	Grid-tied PV inverter	Intertek	2022/06/27		220120057GZU-001, Rev 1	CN-PV-220039R1		Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growco	GX100KT	Grid-tied PV inverter	Intertek	2022/06/27		220307041GZU-001, Rev 1	CN-PV-220070R1		Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growco	GX100KT-F	Grid-tied PV inverter	Intertek	2022/06/27		220307041GZU-001, Rev 1	CN-PV-220070R1		Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growco	GX110KT	Grid-tied PV inverter	Intertek	2022/06/27		220307041GZU-001, Rev 1	CN-PV-220070R1		Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growco	GX110KT-F	Grid-tied PV inverter	Intertek	2022/06/27		220307041GZU-001, Rev 1	CN-PV-220070R1		Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growco	GX136KT-L	Grid-tied PV inverter	Intertek	2022/06/27		220307041GZU-001, Rev 1	CN-PV-220070R1		Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growco	GX136KT-LF	Grid-tied PV inverter	Intertek	2022/06/27		220307041GZU-001, Rev 1	CN-PV-220070R1		Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growco	GX136KT-X	Grid-tied PV inverter	Intertek	2022/06/27		220307041GZU-001, Rev 1	CN-PV-220070R1		Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growco	GX136KT-XF	Grid-tied PV inverter	Intertek	2022/06/27		220307041GZU-001, Rev 1	CN-PV-220070R1		Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growco	GW-MPS0030	Hybrid PV inverter grid-tied	TUV NORD (Hangzhou)	2022/05/24		TRPVP040042/22E01	COCPPV04002/22E-01		Yes	
Growco	GW-MPS0050	Hybrid PV inverter grid-tied	TUV NORD (Hangzhou)	2022/05/24		TRPVP040042/22E01	COCPPV04002/22E-01		Yes	
Growco	GW-MPS0100	Hybrid PV inverter grid-tied	TUV NORD (Hangzhou)	2022/05/24		TRPVP040042/22E01	COCPPV04002/22E-01		Yes	
Growco	GW-MPS0150	Hybrid PV inverter grid-tied	TUV NORD (Hangzhou)	2022/05/24		TRPVP040042/22E01	COCPPV04002/22E-01		Yes	
Growco	GW8KS1	Hybrid PV inverter grid-tied	TUV SUD	2022/10/14		64 290 22 31173.01	D 118596 0001 Rev.00		Yes	
Growco	GW-MPS0250	Hybrid PV inverter grid-tied	TUV Rheinland	2023/02/23		CN229F6J 003	AK 50573567 0001		Yes	
Growco	GW-MPS0500	Hybrid PV inverter grid-tied	TUV Rheinland	2023/02/23		CN229F6J 003	AK 50573567 0001		Yes	
Hoymiles	MI-500	Grid-tied PV inverter	Bureau Veritas	2018/07/10		BMH-18JA0680FCSP-R1	U18-0374		Yes	Hoymiles MI-500, 600 and 700 micro inverters are not equipped with an internal disconnection device and an external City listed network and system grid protection voltage and frequency relay must be provided in the photovoltaic system with appropriately sized two in series contactors according to NRS 097-2-1 requirements and default settings.
Hoymiles	MI-600	Grid-tied PV inverter	Bureau Veritas	2018/07/10		BMH-18JA0680FCSP-R1	U18-0374		Yes	
Hoymiles	MI-700	Grid-tied PV inverter	Bureau Veritas	2018/07/10		BMH-18JA0680FCSP-R1	U18-0374		Yes	
Hoymiles	MI-1000	Grid-tied PV inverter	Bureau Veritas	2018/07/27		ZEM-18AP0889FCSPH	U18-0435		Yes	
Hoymiles	MI-1000T	Grid-tied PV inverter	Bureau Veritas	2018/07/27		ZEM-18AP0889FCSPH	U18-0435		Yes	
Hoymiles	MI-1200	Grid-tied PV inverter	Bureau Veritas	2018/07/27		ZEM-18AP0889FCSPH	U18-0435		Yes	
Hoymiles	MI-1200T	Grid-tied PV inverter	Bureau Veritas	2018/07/27		ZEM-18AP0889FCSPH	U18-0435		Yes	
Hoymiles	HM-500	Grid-tied PV inverter	TUV NORD & Donguan Balun	2021/11/19		TRPVP03078/21B/02	COCPPV03078/21B-02		Yes	
Hoymiles	HM-500T	Grid-tied PV inverter	TUV NORD & Donguan Balun	2021/11/19		TRPVP03078/21B/02	COCPPV03078/21B-02		Yes	
Hoymiles	HM-600	Grid-tied PV inverter	TUV NORD & Donguan Balun	2021/11/19		TRPVP03078/21B/02	COCPPV03078/21B-02		Yes	
Hoymiles	HM-600T	Grid-tied PV inverter	TUV NORD & Donguan Balun	2021/11/19		TRPVP03078/21B/02	COCPPV03078/21B-02		Yes	
Hoymiles	HM-700	Grid-tied PV inverter	TUV NORD & Donguan Balun	2021/11/19		TRPVP03078/21B/02	COCPPV03078/21B-02		Yes	
Hoymiles	HM-700T	Grid-tied PV inverter	TUV NORD & Donguan Balun	2021/11/19		TRPVP03078/21B/02	COCPPV03078/21B-02		Yes	
Hoymiles	HM-800	Grid-tied PV inverter	TUV NORD & Donguan Balun	2021/11/19		TRPVP03078/21B/02	COCPPV03078/21B-02		Yes	
Hoymiles	HM-800T	Grid-tied PV inverter	TUV NORD & Donguan Balun	2021/11/19		TRPVP03078/21B/02	COCPPV03078/21B-02		Yes	
Hoymiles	HM-1000	Grid-tied PV inverter	TUV NORD & Donguan Balun	2021/11/19		TRPVP03078/21B/01	COCPPV03078/21B-01		Yes	
Hoymiles	HM-1000T	Grid-tied PV inverter	TUV NORD & Donguan Balun	2021/11/19		TRPVP03078/21B/01	COCPPV03078/21B-01		Yes	
Hoymiles	HM-1200	Grid-tied PV inverter	TUV NORD & Donguan Balun	2021/11/19		TRPVP03078/21B/01	COCPPV03078/21B-01		Yes	
Hoymiles	HM-1200T	Grid-tied PV inverter	TUV NORD & Donguan Balun	2021/11/19		TRPVP03078/21B/01	COCPPV03078/21B-01		Yes	
Hoymiles	HM-1500	Grid-tied PV inverter	TUV NORD & Donguan Balun	2021/11/19		TRPVP03078/21B/01	COCPPV03078/21B-01		Yes	
Hoymiles	HM-1500T	Grid-tied PV inverter	TUV NORD & Donguan Balun	2021/11/19		TRPVP03078/21B/01	COCPPV03078/21B-01		Yes	
Huawei	SUN 2000-50KTL-MO	Grid-tied PV inverter	TUV SUD	2018/09/21		70 409 18 051 24-01	D 041829 3318		Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Huawei	SUN 2000-60KTL-MO	Grid-tied PV inverter	TUV SUD	2018/09/21		70 409 18 051 24-01	D 041829 3318		Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Huawei	SUN 2000-36KTL	Grid-tied PV inverter	Bureau Veritas	2020/04/24		PVZA180718N004	1888AP0718N004001		Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Huawei	SUN 2000-100KTL-M1	Grid-tied PV inverter	Bureau Veritas	2020/05/29		PVZA200521N034	2088AP0521N034001		Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Huawei	SUN 2000-2KTL-L1	Hybrid PV inverter grid-tied	Bureau Veritas	2021/02/08		PVZA21011WDG0170	2188AP010170001		Yes	
Huawei	SUN 2000-3KTL-L1	Hybrid PV inverter grid-tied	Bureau Veritas	2021/02/08		PVZA21011WDG0170	2188AP010170001		Yes	
Huawei	SUN 2000-3.68KTL-L1	Hybrid PV inverter grid-tied	Bureau Veritas	2021/02/08		PVZA21011WDG0170	2188AP010170001		Yes	
Huawei	SUN 2000-4KTL-L1	Hybrid PV inverter grid-tied	Bureau Veritas	2021/02/08		PVZA21011WDG0170	2188AP010170001		Yes	
Huawei	SUN 2000-4.6KTL-L1	Hybrid PV inverter grid-tied	Bureau Veritas	2021/02/08		PVZA21011WDG0170	2188AP010170001		Yes	

Jinko	JKS-3HLVS-HI	Hybrid PV inverter grid-tied	TÜV SÜD	2023/04/14	64.290.23.30521.01	D 118443 0019 Rev.00		Yes	
Jinko	JKS-3.6HLVS-HI	Hybrid PV inverter grid-tied	TÜV SÜD	2023/04/14	64.290.23.30521.01	D 118443 0019 Rev.00		Yes	
Jinko	JKS-4HLVS-HI	Hybrid PV inverter grid-tied	TÜV SÜD	2023/04/14	64.290.23.30521.01	D 118443 0019 Rev.00		Yes	
Jinko	JKS-4.6HLVS-HI	Hybrid PV inverter grid-tied	TÜV SÜD	2023/04/14	64.290.23.30521.01	D 118443 0019 Rev.00		Yes	
Jinko	JKS-5HLVS-HI	Hybrid PV inverter grid-tied	TÜV SÜD	2023/04/14	64.290.23.30521.01	D 118443 0019 Rev.00		Yes	
Jinko	JKS-6HLVS-HI	Hybrid PV inverter grid-tied	TÜV SÜD	2023/04/14	64.290.23.30521.01	D 118443 0019 Rev.00		Yes	
Kehua	BCS50K-A	Battery based inverter grid-tied	TÜV SÜD	2022/09/22	64.290.22.30151.01	D 115067 0036 Rev.00		Yes	The energy storage inverter is not equipped with integrated network and system (NS) protection. External to the converter NS protection required with a City listed NS grid protection voltage and frequency relay and appropriately sized two in series contactors according to NRS 097-2-1 requirements and default settings.
Kehua	BCS100K-A	Battery based inverter grid-tied	TÜV SÜD	2022/09/22	64.290.22.30151.01	D 115067 0036 Rev.00		Yes	The energy storage inverter is not equipped with integrated network and system (NS) protection. External to the converter NS protection required with a City listed NS grid protection voltage and frequency relay and appropriately sized two in series contactors according to NRS 097-2-1 requirements and default settings.
Kehua	BCS250K-A	Battery based inverter grid-tied	TÜV SÜD	2022/09/22	64.290.22.30151.01	D 115067 0036 Rev.00		Yes	The energy storage inverter is not equipped with integrated network and system (NS) protection. External to the converter NS protection required with a City listed NS grid protection voltage and frequency relay and appropriately sized two in series contactors according to NRS 097-2-1 requirements and default settings.
Kehua	BCS500K-A	Battery based inverter grid-tied	TÜV SÜD	2022/09/22	64.290.22.30151.01	D 115067 0036 Rev.00		Yes	The energy storage inverter is not equipped with integrated network and system (NS) protection. External to the converter NS protection required with a City listed NS grid protection voltage and frequency relay and appropriately sized two in series contactors according to NRS 097-2-1 requirements and default settings.
Kodak	Kodak I3.0	Grid-tied PV inverter	Dekra	2019/12/10	6065813.50	6065813.01AOC	Yes		
Kodak	Kodak I3.6	Grid-tied PV inverter	Dekra	2019/12/10	6065813.50	6065813.01AOC	Yes		
Kodak	Kodak I4.6	Grid-tied PV inverter	Dekra	2019/12/10	6065813.50	6065813.01AOC	Yes		
Kodak	Kodak H3.0	Hybrid PV inverter grid-tied	TUV Rheinland	2019/12/17	50173405.002	AK 50454890.0001	Yes		
Kodak	Kodak H3.6	Hybrid PV inverter grid-tied	TUV Rheinland	2019/12/17	50173405.002	AK 50454890.0001	Yes		
Kodak	Kodak H4.6	Hybrid PV inverter grid-tied	TUV Rheinland	2019/12/17	50173405.002	AK 50454890.0001	Yes		
Koyoe	KY-1Hybrid-5k0-H	Hybrid PV inverter grid-tied	Intertek	2021/01/22	201102063GZU-001	CN-PV-210016		Yes	
Koyoe	KY-1Hybrid-5k0-H-A	Hybrid PV inverter grid-tied	Intertek	2021/08/21	210525156GZU-001	CN-PV-210154		Yes	
Koyoe	KY-EST06KH-A	Hybrid PV inverter grid-tied	TUV NORD	2021/12/30	TRPPVP04039/21E.09	COCPPVP04039/21E-02	Yes		
Koyoe	KY-EST08KH-A	Hybrid PV inverter grid-tied	TUV NORD	2021/12/30	TRPPVP04039/21E.09	COCPPVP04039/21E-02	Yes		
Koyoe	KY-EST10KH-A	Hybrid PV inverter grid-tied	TUV NORD	2021/12/30	TRPPVP04039/21E.09	COCPPVP04039/21E-02	Yes		
Koyoe	KY-EST12KH-A	Hybrid PV inverter grid-tied	TUV NORD	2021/12/30	TRPPVP04039/21E.09	COCPPVP04039/21E-02	Yes		
Koyoe	KY-EST17KH-A	Hybrid PV inverter grid-tied	TUV NORD	2021/12/30	TRPPVP04039/21E.09	COCPPVP04039/21E-02	Yes		
Koyoe	KY-EST20KH-A	Hybrid PV inverter grid-tied	TUV NORD	2021/12/30	TRPPVP04039/21E.09	COCPPVP04039/21E-02	Yes		
Koyoe	KY-EST06KH	Hybrid PV inverter grid-tied	TUV NORD	2021/10/15	TRPPVP04039/21E.04	COCPPVP04039/21E-01	Yes		
Koyoe	KY-EST08KH	Hybrid PV inverter grid-tied	TUV NORD	2021/10/15	TRPPVP04039/21E.04	COCPPVP04039/21E-01	Yes		
Koyoe	KY-EST10KH	Hybrid PV inverter grid-tied	TUV NORD	2021/10/15	TRPPVP04039/21E.04	COCPPVP04039/21E-01	Yes		
Koyoe	KY-EST15KH	Hybrid PV inverter grid-tied	TUV NORD	2021/10/15	TRPPVP04039/21E.04	COCPPVP04039/21E-01	Yes		
Koyoe	KY-EST17KH	Hybrid PV inverter grid-tied	TUV NORD	2021/10/15	TRPPVP04039/21E.04	COCPPVP04039/21E-01	Yes		
Koyoe	KY-EST20KH	Hybrid PV inverter grid-tied	TUV NORD	2021/10/15	TRPPVP04039/21E.04	COCPPVP04039/21E-01	Yes		
KSTAR	Blue-S 3680D	Hybrid PV inverter grid-tied	TUV SÜD	2021/09/23	64.290.20.30989.03	D 075386 0136 Rev.02	Yes		
KSTAR	Blue-S 5000D	Hybrid PV inverter grid-tied	TUV SÜD	2021/09/23	64.290.20.30989.03	D 075386 0136 Rev.02	Yes		
KSTAR	Blue-S 3680D-M1	Hybrid PV inverter grid-tied	TUV SÜD	2021/09/23	64.290.20.30989.03	D 075386 0136 Rev.02	Yes		
KSTAR	Blue-S 5000D-M1	Hybrid PV inverter grid-tied	TUV SÜD	2021/09/23	64.290.20.30989.03	D 075386 0136 Rev.02	Yes		
KSTAR	Blue-G 3000S	Grid-tied PV inverter	TUV SÜD	2021/09/23	64.290.21.30004.03	D 075386 0137 Rev.02	Yes		
KSTAR	Blue-G 3000S-M1	Grid-tied PV inverter	TUV SÜD	2021/09/23	64.290.21.30004.03	D 075386 0137 Rev.02	Yes		
KSTAR	Blue-G 3000D	Grid-tied PV inverter	TUV SÜD	2021/09/23	64.290.21.30004.03	D 075386 0137 Rev.02	Yes		
KSTAR	Blue-G 3000D-M0	Grid-tied PV inverter	TUV SÜD	2021/09/23	64.290.21.30004.03	D 075386 0137 Rev.02	Yes		
KSTAR	Blue-G 3000D-M1	Grid-tied PV inverter	TUV SÜD	2021/09/23	64.290.21.30004.03	D 075386 0137 Rev.02	Yes		
KSTAR	Blue-G 3600D	Grid-tied PV inverter	TUV SÜD	2021/09/23	64.290.21.30004.03	D 075386 0137 Rev.02	Yes		
KSTAR	Blue-G 3600D-M0	Grid-tied PV inverter	TUV SÜD	2021/09/23	64.290.21.30004.03	D 075386 0137 Rev.02	Yes		
KSTAR	Blue-G 3600D-M1	Grid-tied PV inverter	TUV SÜD	2021/09/23	64.290.21.30004.03	D 075386 0137 Rev.02	Yes		
KSTAR	Blue-G 4000D	Grid-tied PV inverter	TUV SÜD	2021/09/23	64.290.21.30004.03	D 075386 0137 Rev.02	Yes		
KSTAR	Blue-G 4000D-M0	Grid-tied PV inverter	TUV SÜD	2021/09/23	64.290.21.30004.03	D 075386 0137 Rev.02	Yes		
KSTAR	Blue-G 4000D-M1	Grid-tied PV inverter	TUV SÜD	2021/09/23	64.290.21.30004.03	D 075386 0137 Rev.02	Yes		
KSTAR	Blue-G 4200D	Grid-tied PV inverter	TUV SÜD	2021/09/23	64.290.21.30004.03	D 075386 0137 Rev.02	Yes		
KSTAR	Blue-G 4200D-M0	Grid-tied PV inverter	TUV SÜD	2021/09/23	64.290.21.30004.03	D 075386 0137 Rev.02	Yes		
KSTAR	Blue-G 4200D-M1	Grid-tied PV inverter	TUV SÜD	2021/09/23	64.290.21.30004.03	D 075386 0137 Rev.02	Yes		
KSTAR	Blue-G 4600D	Grid-tied PV inverter	TUV SÜD	2021/09/23	64.290.21.30004.03	D 075386 0137 Rev.02	Yes		
KSTAR	Blue-G 4600D-M1	Grid-tied PV inverter	TUV SÜD	2021/09/23	64.290.21.30004.03	D 075386 0137 Rev.02	Yes		
Lifelynk	Life3.5Hyb02	Hybrid PV inverter grid-tied	Dongguan Balun	2022/05/19	BL-DG2240044-B01	BL-DG2240044D01	Yes		
Lifelynk	Life3.3Hyb02	Hybrid PV inverter grid-tied	Dongguan Balun	2022/05/19	BL-DG2240044-B01	BL-DG2240044D01	Yes		
Livolttek	Hyper-2000	Hybrid PV inverter grid-tied	Dekra	2019/07/05	6055811.50	6055811.01AOC	Yes		
Livolttek	Hyper-3000	Hybrid PV inverter grid-tied	Dekra	2019/07/05	6055811.50	6055811.01AOC	Yes		
Livolttek	Hyper-3680	Hybrid PV inverter grid-tied	Dekra	2019/07/05	6055811.50	6055811.01AOC	Yes		
Livolttek	Hyper-4600	Hybrid PV inverter grid-tied	Dekra	2019/07/05	6055811.50	6055811.01AOC	Yes		
Livolttek	Hyper-5000	Hybrid PV inverter grid-tied	Dekra	2019/07/05	6055811.50	6055811.01AOC	Yes		
Livolttek	Retro-2000	Battery based inverter grid-tied	Dekra	2019/07/05	6055811.50	6055811.01AOC	Yes		
Livolttek	Retro-3000	Battery based inverter grid-tied	Dekra	2019/07/05	6055811.50	6055811.01AOC	Yes		
Livolttek	Retro-3680	Battery based inverter grid-tied	Dekra	2019/07/05	6055811.50	6055811.01AOC	Yes		
Livolttek	Retro-4600	Battery based inverter grid-tied	Dekra	2019/07/05	6055811.50	6055811.01AOC	Yes		
Livolttek	Retro-5000	Battery based inverter grid-tied	Dekra	2019/07/05	6055811.50	6055811.01AOC	Yes		
Lovato	PMVF 80	Network & system relay	TÜV SÜD	2020/10/28	TR-486879-82695-04 (Ed 01)	D 084111 Rev. 00	No	No	network and system grid protection voltage and frequency relay only in accordance with DIN VDE 0124-100 and VDE-AR-N 4105:2018-11. Must be programmed to NRS 097-2-1 or the applicable South African Grid Codes and may only be used in conjunction with approved NRS 097-2-1 type tested inverters on this list.
Lux Power	LXP 3K Hybrid	Hybrid PV inverter grid-tied	Intertek	2019/08/29	190624070GZU-001	CN-PV-190006	Yes		
Lux Power	LXP 4K Hybrid	Hybrid PV inverter grid-tied	Intertek	2019/08/29	190624070GZU-001	CN-PV-190006	Yes		
Lux Power	LXP 5K Hybrid	Hybrid PV inverter grid-tied	Intertek	2019/08/29	190624070GZU-001	CN-PV-190006	Yes		
Lux Power	LXP-LB-EU 8K	Hybrid PV inverter grid-tied	Intertek	2022/08/16	211111140GZU-001	CN-PV-220166		Yes	
Lux Power	LXP-LB-EU 10K	Hybrid PV inverter grid-tied	Intertek	2022/08/16	211111140GZU-001	CN-PV-220166		Yes	
Lux Power	LXP-LB-EU 12K	Hybrid PV inverter grid-tied	Intertek	2022/08/22	220630104GZU-001	CN-PV-220171		Yes	
Lux Power	SNA3000 WPV	Hybrid PV inverter grid-tied	Intertek	2023/05/31	230315003GZU-001	CN-PV-230280		Yes	
Lux Power	SNA4000 WPV	Hybrid PV inverter grid-tied	Intertek	2023/05/31	230315003GZU-001	CN-PV-230280		Yes	
Lux Power	SNA5000 WPV	Hybrid PV inverter grid-tied	Intertek	2023/05/31	230315003GZU-001	CN-PV-230280		Yes	

Lux Power	SNA6000 WPV	Hybrid PV inverter grid-tied	Intertek	2023/05/31	230315003GZU-001	CN-PV-230280	Yes	
Mecer	Mecer Sol-IS-10M	Hybrid PV inverter grid-tied	Bureau Veritas	2020/10/30	PVZA180904N057-R1	2088AP0923N001002	Yes	
Megarevo	R3KL1	Hybrid PV inverter grid-tied	TUV SUD	2022/01/14	64.290.21.30686.01	D 115385 0001 Rev.00	Yes	
Megarevo	R3K6L1	Hybrid PV inverter grid-tied	TUV SUD	2022/01/14	64.290.21.30686.01	D 115385 0001 Rev.00	Yes	
Megarevo	R4KL1	Hybrid PV inverter grid-tied	TUV SUD	2022/01/14	64.290.21.30686.01	D 115385 0001 Rev.00	Yes	
Megarevo	R4K6L1	Hybrid PV inverter grid-tied	TUV SUD	2022/01/14	64.290.21.30686.01	D 115385 0001 Rev.00	Yes	
Megarevo	R5KL1	Hybrid PV inverter grid-tied	TUV SUD	2022/01/14	64.290.21.30686.01	D 115385 0001 Rev.00	Yes	
Megarevo	R6KL1	Hybrid PV inverter grid-tied	TUV SUD	2022/01/14	64.290.21.30686.01	D 115385 0001 Rev.00	Yes	
Megarevo	R8KL1	Hybrid PV inverter grid-tied	TUV SUD	2022/01/26	64.290.21.30636.01	D 115385 0002 Rev.00	Yes	
Midea	ME-HS8L	Hybrid PV inverter grid-tied	TUV SUD	2023/04/26	64.290.23.30325.01	D 072433 1250 Rev.00	Yes	
Ohm	OHM-8K-W	Hybrid PV inverter grid-tied	Shenzhen Balun	2020/02/26	BL-SZ1910095-B02	BL-SZ1910095-D02	Yes	
Ohm	OHM-7.6K-W	Hybrid PV inverter grid-tied	Shenzhen Balun	2020/02/26	BL-SZ1910095-B02	BL-SZ1910095-D02	Yes	
Ohm	OHM-6K-W	Hybrid PV inverter grid-tied	Shenzhen Balun	2020/02/26	BL-SZ1910095-B02	BL-SZ1910095-D02	Yes	
Ohm	OHM-5K-W	Hybrid PV inverter grid-tied	Shenzhen Balun	2020/02/26	BL-SZ1910095-B02	BL-SZ1910095-D02	Yes	
Ohm	OHM-3.6K-W	Hybrid PV inverter grid-tied	Shenzhen Balun	2020/02/26	BL-SZ1910095-B02	BL-SZ1910095-D02	Yes	
Onesto	OST 4600HB-60	Hybrid PV inverter grid-tied	TUV Rheinland	2023/05/11	CN23UTJN 001	AK 50580973 0001	Yes	
Onesto	OST 5000HB-60	Hybrid PV inverter grid-tied	TUV Rheinland	2023/05/11	CN23UTJN 001	AK 50580973 0001	Yes	
Onesto	OST 6000HB-60	Hybrid PV inverter grid-tied	TUV Rheinland	2023/05/11	CN23UTJN 001	AK 50580973 0001	Yes	
Onesto	OST 4600HB-120	Hybrid PV inverter grid-tied	TUV Rheinland	2023/05/11	CN23UTJN 001	AK 50580973 0001	Yes	
Onesto	OST 5000HB-120	Hybrid PV inverter grid-tied	TUV Rheinland	2023/05/11	CN23UTJN 001	AK 50580973 0001	Yes	
Onesto	OST 6000HB-120	Hybrid PV inverter grid-tied	TUV Rheinland	2023/05/11	CN23UTJN 001	AK 50580973 0001	Yes	
Onesto	OST 4K6AC	Battery based inverter grid-tied	TUV Rheinland	2023/05/11	CN23UTJN 001	AK 50580973 0001	Yes	
Onesto	OST 5KAC	Battery based inverter grid-tied	TUV Rheinland	2023/05/11	CN23UTJN 001	AK 50580973 0001	Yes	
Onesto	OST 6KAC	Battery based inverter grid-tied	TUV Rheinland	2023/05/11	CN23UTJN 001	AK 50580973 0001	Yes	
Ouco	M3KES	Hybrid PV inverter grid-tied	TUV SUD	2022/01/25	64.290.22.30047.01	D 115420 0001 Rev.00	Yes	
Ouco	M3K6ES	Hybrid PV inverter grid-tied	TUV SUD	2022/01/25	64.290.22.30047.01	D 115420 0001 Rev.00	Yes	
Ouco	M4KES	Hybrid PV inverter grid-tied	TUV SUD	2022/01/25	64.290.22.30047.01	D 115420 0001 Rev.00	Yes	
Ouco	M4K6ES	Hybrid PV inverter grid-tied	TUV SUD	2022/01/25	64.290.22.30047.01	D 115420 0001 Rev.00	Yes	
Ouco	M5KES	Hybrid PV inverter grid-tied	TUV SUD	2022/01/25	64.290.22.30047.01	D 115420 0001 Rev.00	Yes	
Ouco	M6KES	Hybrid PV inverter grid-tied	TUV SUD	2022/01/25	64.290.22.30047.01	D 115420 0001 Rev.00	Yes	
Ouco	M8KDS	Hybrid PV inverter grid-tied	TUV SUD	2022/01/27	64.290.22.30048.01	D 115420 0002 Rev.00	Yes	
PowerTannk	GH-3KHL	Hybrid PV inverter grid-tied	TUV SUD	2022/11/11	64.290.22.31476.01	D 110578 0002 Rev.00	Yes	
PowerTannk	GH-3K6HL	Hybrid PV inverter grid-tied	TUV SUD	2022/11/11	64.290.22.31476.01	D 110578 0002 Rev.00	Yes	
PowerTannk	GH-4KHL	Hybrid PV inverter grid-tied	TUV SUD	2022/11/11	64.290.22.31476.01	D 110578 0002 Rev.00	Yes	
PowerTannk	GH-4K6HL	Hybrid PV inverter grid-tied	TUV SUD	2022/11/11	64.290.22.31476.01	D 110578 0002 Rev.00	Yes	
PowerTannk	GH-5KHL	Hybrid PV inverter grid-tied	TUV SUD	2022/11/11	64.290.22.31476.01	D 110578 0002 Rev.00	Yes	
PowerTannk	GH-6KHL	Hybrid PV inverter grid-tied	TUV SUD	2022/11/11	64.290.22.31476.01	D 110578 0002 Rev.00	Yes	
Rentech	HYD 3000-EP	Hybrid PV inverter grid-tied	Intertek	2020/12/22	201207035GZU-001	CN-PV-200172	Yes	
Rentech	HYD 3600-EP	Hybrid PV inverter grid-tied	Intertek	2020/12/22	201207035GZU-001	CN-PV-200172	Yes	
Rentech	HYD 4000-EP	Hybrid PV inverter grid-tied	Intertek	2020/12/22	201207035GZU-001	CN-PV-200172	Yes	
Rentech	HYD 4600-EP	Hybrid PV inverter grid-tied	Intertek	2020/12/22	201207035GZU-001	CN-PV-200172	Yes	
Rentech	HYD 5000-EP	Hybrid PV inverter grid-tied	Intertek	2020/12/22	201207035GZU-001	CN-PV-200172	Yes	
Rentech	HYD 5500-EP	Hybrid PV inverter grid-tied	Intertek	2020/12/22	201207035GZU-001	CN-PV-200172	Yes	
Rentech	HYD 6000-EP	Hybrid PV inverter grid-tied	Intertek	2020/12/22	201207035GZU-001	CN-PV-200172	Yes	
Rentech	INFINISOLAR PLUS 5 kW	Hybrid PV inverter grid-tied	Bureau Veritas	2021/03/20	PVZA2101W0G0269	2188AP0689001	Yes	
Royal	RH 3.6K-1PLVG1-EU	Hybrid PV inverter grid-tied	Intertek	2022/10/17	220600667SHA-004	CN-PV-220212R1	Yes	
Royal	RH 4K-1PLVG1-EU	Hybrid PV inverter grid-tied	Intertek	2022/10/17	220600667SHA-004	CN-PV-220212R1	Yes	
Royal	RH 4.6K-1PLVG1-EU	Hybrid PV inverter grid-tied	Intertek	2022/10/17	220600667SHA-004	CN-PV-220212R1	Yes	
Royal	RH 5K-1PLVG1-EU	Hybrid PV inverter grid-tied	Intertek	2022/10/17	220600667SHA-004	CN-PV-220212R1	Yes	
SAJ	H1-3K-S2	Hybrid PV inverter grid-tied	TUV SUD	2022/11/18	64.290.20.30788.02	D 077831 0019 Rev.01	Yes	
SAJ	H1-3.6K-S2	Hybrid PV inverter grid-tied	TUV SUD	2022/11/18	64.290.20.30788.02	D 077831 0019 Rev.01	Yes	
SAJ	H1-4K-S2	Hybrid PV inverter grid-tied	TUV SUD	2022/11/18	64.290.20.30788.02	D 077831 0019 Rev.01	Yes	
SAJ	H1-4.6K-S2	Hybrid PV inverter grid-tied	TUV SUD	2022/11/18	64.290.20.30788.02	D 077831 0019 Rev.01	Yes	
SAJ	H1-5K-S2	Hybrid PV inverter grid-tied	TUV SUD	2022/11/18	64.290.20.30788.02	D 077831 0019 Rev.01	Yes	
SAJ	H1-4.6K-S2	Hybrid PV inverter grid-tied	TUV SUD	2022/11/18	64.290.20.30788.02	D 077831 0019 Rev.01	Yes	
SAJ	H1-5K-S2	Hybrid PV inverter grid-tied	TUV SUD	2022/11/18	64.290.20.30788.02	D 077831 0019 Rev.01	Yes	
Schneider	Conext CL-60E	Grid-tied PV inverter	TUV Rheinland	2018/02/09	701261703501-01	D 18 01 96208 006	Yes	
Schneider	XW+8548E	Battery based inverter grid-tied	TUV Rheinland	2020/08/11	50329684 002	AK 50477341 0001	Yes	
Schneider	CL 33	Grid-tied PV inverter	TUV NORD & Shenzhen Balun	2021/02/09	TRPVP11115/20B/01_R2	COCPPVP11115/20B_R1	Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Schneider	CL50	Grid-tied PV inverter	TUV NORD & Shenzhen Balun	2021/02/09	TRPVP11115/20B/01_R2	COCPPVP11115/20B_R1	Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Sermatec	SMT-5K-TL-LV	Hybrid PV inverter grid-tied	TUV SUD	2019/06/25	64.290.19.01426.01	D 102650 0007	Yes	
Sermatec	SMT-10K-TL-TH	Hybrid PV inverter grid-tied	TUV SUD	2019/07/25	64.290.18.04743.01	D 102650 0009	Yes	
Sineng	SP-120K-BL	Grid-tied PV inverter	TUV SUD	2022/12/28	70.409.22.302.06-00 A1	D 091566 0040 Rev.00	Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Sineng	SP-120K-L	Grid-tied PV inverter	TUV SUD	2022/12/28	70.409.22.302.06-00 A1	D 091566 0040 Rev.00	Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Sinexcel	PWG2-50K-EX	Hybrid PV inverter grid-tied	TUV SUD	2021/09/10	64.290.21.30201.02	D 076777 0016 Rev. 01	Yes	Inverter may only be used in plants according to Category A3: 100 kVA - 1MVA. Inverter not equipped with an internal disconnection device and an external City listed network and system grid protection voltage and frequency relay must be provided with appropriately sized electromechanical switches.
Sinexcel	PWG2-100K-EX	Hybrid PV inverter grid-tied	TUV SUD	2021/09/10	64.290.21.30201.02	D 076777 0016 Rev. 01	Yes	Inverter may only be used in plants according to Category A3: 100 kVA - 1MVA. Inverter not equipped with an internal disconnection device and an external City listed network and system grid protection voltage and frequency relay must be provided with appropriately sized electromechanical switches. Inverter may only be used in plants according to Category A3: 100 kVA - 1MVA and connection to the grid via an external customer MV/LV AC transformer.
SMA	STP50-40	Grid-tied PV inverter	Bureau Veritas	2023/03/08	17TH0199-NRS 097-2-1_4	U23-0185	Yes	Inverter may only be used in plants according to Category A3: 100 kVA - 1MVA and connection to the grid via an external customer MV/LV AC transformer.
SMA	STP50-41	Grid-tied PV inverter	Bureau Veritas	2023/03/08	17TH0199-NRS 097-2-1_4	U23-0185	Yes	Inverter may only be used in plants according to Category A3: 100 kVA - 1MVA and connection to the grid via an external customer MV/LV AC transformer.
SMA	STP60-10	Grid-tied PV inverter	Bureau Veritas	2018/09/26	14TH0075-NRS 097-2-1_3	U18-0451	Yes	Inverter may only be used in plants according to Category A3: 100 kVA - 1MVA and connection to the grid via an external customer MV/LV AC transformer.
SMA	SHP75-10	Grid-tied PV inverter	Bureau Veritas	2018/09/26	14TH0075-NRS 097-2-1_3	U18-0451	Yes	Inverter may only be used in plants according to Category A3: 100 kVA - 1MVA and connection to the grid via an external customer MV/LV AC transformer.
SMA	STPS 60-10	Battery based PV inverter grid-tied	Bureau Veritas	2018/09/26	14TH0075-NRS 097-2-1_3	U18-0451	Yes	Inverter may only be used in plants according to Category A3: 100 kVA - 1MVA and connection to the grid via an external customer MV/LV AC transformer.
SMA	SB3.0-1AV-41	Grid-tied PV inverter	Bureau Veritas	2023/01/20	16TH0348-NRS 097-2-1_1	U23-0041	Yes	
SMA	SB3.6-1AV-41	Grid-tied PV inverter	Bureau Veritas	2023/01/20	16TH0348-NRS 097-2-1_1	U23-0041	Yes	
SMA	SB4.0-1AV-41	Grid-tied PV inverter	Bureau Veritas	2023/01/20	16TH0348-NRS 097-2-1_1	U23-0041	Yes	

SMA	SBS 0-1AV-41	Grid-tied PV inverter	Bureau Veritas	2023/01/20	16TH0348-NRS 097-2-1 1	U23-0041	Yes	
SMA	SBS 0-1AV-41	Grid-tied PV inverter	Bureau Veritas	2023/01/20	16TH0348-NRS 097-2-1 1	U23-0041	Yes	
SMA	STP 15000TL-30	Grid-tied PV inverter	Bureau Veritas	2020/08/13	14TH0304-NRS 097-2-1-2017_0	U20-0641	Yes	
SMA	STP 20000TL-30	Grid-tied PV inverter	Bureau Veritas	2020/08/13	14TH0304-NRS 097-2-1-2017_0	U20-0641	Yes	
SMA	STP 25000TL-30	Grid-tied PV inverter	Bureau Veritas	2020/08/13	14TH0304-NRS 097-2-1-2017_0	U20-0641	Yes	
SMA	STP 110-60	Grid-tied PV inverter	TUV SUD	2021/01/21	704092001861-00	D 0701202019 Rev.00	Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
SMA	STP3 0-3AV-40	Grid-tied PV inverter	Bureau Veritas	2021/07/14	18TH0325-NRS-2-1 0	U21-0661	Yes	
SMA	STP4 0-3AV-40	Grid-tied PV inverter	Bureau Veritas	2021/07/14	18TH0325-NRS-2-1 0	U21-0661	Yes	
SMA	STP6 0-3AV-40	Grid-tied PV inverter	Bureau Veritas	2021/07/14	18TH0325-NRS-2-1 0	U21-0661	Yes	
SMA	STP6 0-3AV-40	Grid-tied PV inverter	Bureau Veritas	2021/07/14	18TH0325-NRS-2-1 0	U21-0661	Yes	
SMA	STP6 0-3AV-40	Grid-tied PV inverter	Bureau Veritas	2021/07/14	18TH0325-NRS-2-1 0	U21-0661	Yes	
SMA	STP10 0-3AV-40	Grid-tied PV inverter	Bureau Veritas	2021/07/14	18TH0325-NRS-2-1 0	U21-0661	Yes	
SMA	STP5 0-3SE-40	Hybrid PV inverter grid-tied	TUV Rheinland	2022/02/21	CN210918 001	AK 50510847 0001	Yes	
SMA	STP6 0-3SE-40	Hybrid PV inverter grid-tied	TUV Rheinland	2022/02/21	CN210918 001	AK 50510847 0001	Yes	
SMA	STP8 0-3SE-40	Hybrid PV inverter grid-tied	TUV Rheinland	2022/02/21	CN210918 001	AK 50510847 0001	Yes	
SMA	STP10 0-3SE-40	Hybrid PV inverter grid-tied	TUV Rheinland	2022/02/21	CN210918 001	AK 50510847 0001	Yes	
SMA	STP12-50	Grid-tied PV inverter	TUV SUD	2023/04/03	713254379-006	ESY 070122 0044 Rev.00	Yes	
SMA	STP15-50	Grid-tied PV inverter	TUV SUD	2023/04/03	713254379-006	ESY 070122 0044 Rev.00	Yes	
SMA	STP20-50	Grid-tied PV inverter	TUV SUD	2023/04/03	713254379-006	ESY 070122 0044 Rev.00	Yes	
SMA	STP25-50	Grid-tied PV inverter	TUV SUD	2023/04/03	713254379-006	ESY 070122 0044 Rev.00	Yes	
Solar Solar	HYD 6000-ES	Hybrid PV inverter grid-tied	Intertek	2019/07/16	190603089GZU-001	190603089GZU-001	Yes	
Solar Solar	HYD 5000-ES	Hybrid PV inverter grid-tied	Intertek	2019/07/16	190603089GZU-001	190603089GZU-001	Yes	
Solar Solar	HYD 4000-ES	Hybrid PV inverter grid-tied	Intertek	2019/07/16	190603089GZU-001	190603089GZU-001	Yes	
Solar Solar	HYD 3600-ES	Hybrid PV inverter grid-tied	Intertek	2019/07/16	190603089GZU-001	190603089GZU-001	Yes	
Solar Solar	HYD 3000-ES	Hybrid PV inverter grid-tied	Intertek	2019/07/16	190603089GZU-001	190603089GZU-001	Yes	
Solar Solar	6000TL	Grid-tied PV inverter	Intertek	2019/12/19	191025090GZU-001	CN-PV-190090	Yes	
Solar Solar	5000TL	Grid-tied PV inverter	Intertek	2019/12/19	191025090GZU-001	CN-PV-190090	Yes	
Solar Solar	HYD 8KTL-3PH	Hybrid PV inverter grid-tied	Shenzhen Balun	2020/07/10	BL-DG2060517-B01	BL-DG2060517D01	Yes	
Solar Solar	HYD 8KTL-3PH	Hybrid PV inverter grid-tied	Shenzhen Balun	2020/07/10	BL-DG2060517-B01	BL-DG2060517D01	Yes	
Solar Solar	HYD 8KTL-3PH	Hybrid PV inverter grid-tied	Shenzhen Balun	2020/07/10	BL-DG2060517-B01	BL-DG2060517D01	Yes	
Solar Solar	HYD 10KTL-3PH	Hybrid PV inverter grid-tied	Shenzhen Balun	2020/07/10	BL-DG2060517-B01	BL-DG2060517D01	Yes	
Solar Solar	HYD 15KTL-3PH	Hybrid PV inverter grid-tied	Shenzhen Balun	2020/07/10	BL-DG2060517-B01	BL-DG2060517D01	Yes	
Solar Solar	HYD 20KTL-3PH	Hybrid PV inverter grid-tied	Shenzhen Balun	2020/07/10	BL-DG2060517-B01	BL-DG2060517D01	Yes	
Solar Solar	SKTLM-G3	Grid-tied PV inverter	Intertek	2021/08/09	210715145GZU-002	CN-PV-210185	Yes	
Solar Solar	3.6KTL-M-G3	Grid-tied PV inverter	Intertek	2021/08/09	210715145GZU-002	CN-PV-210185	Yes	
Solar Solar	4KTL-M-G3	Grid-tied PV inverter	Intertek	2021/08/09	210715145GZU-002	CN-PV-210185	Yes	
Solar Solar	4.6KTL-M-G3	Grid-tied PV inverter	Intertek	2021/08/09	210715145GZU-002	CN-PV-210185	Yes	
Solar Solar	5KTL-M-G3	Grid-tied PV inverter	Intertek	2021/08/09	210715145GZU-002	CN-PV-210185	Yes	
Solar Solar	SKTLM-G3-A	Grid-tied PV inverter	Intertek	2021/08/09	210715145GZU-002	CN-PV-210185	Yes	
Solar Solar	6KTL-M-G3	Grid-tied PV inverter	Intertek	2021/08/09	210715145GZU-002	CN-PV-210185	Yes	
SolarEdge	SE25K	Grid-tied PV inverter	Bureau Veritas	2020/12/19	19TH0534-NRS 097-2-1 2	U20-1043	Yes	Grid connection inverter for 230 V, L-N / 400Vac, L-L output only and is intended with and without AC transformer for Category A2 and A3 plant.
SolarEdge	SE27.6K	Grid-tied PV inverter	Bureau Veritas	2020/12/19	19TH0534-NRS 097-2-1 2	U20-1043	Yes	Grid connection inverter for 230 V, L-N / 400Vac, L-L output only and is intended with and without AC transformer for Category A2 and A3 plant.
SolarEdge	SE30K	Grid-tied PV inverter	Bureau Veritas	2020/12/19	19TH0534-NRS 097-2-1 2	U20-1043	Yes	For 277 Vac L-N / 480 Vac L-L, grid inverter may only be used in plants according to Category A3: 100 kVA - 1MVA and connection to the grid via an external customer MV/LV AC transformer. Grid connection inverter with 230 V, L-N / 400Vac, L-L output is intended with and without AC transformer for Category A2 and A3 plant.
SolarEdge	SE33.3K	Grid-tied PV inverter	Bureau Veritas	2020/12/19	19TH0534-NRS 097-2-1 2	U20-1043	Yes	For 277 Vac L-N / 480 Vac L-L, grid inverter may only be used in plants according to Category A3: 100 kVA - 1MVA and connection to the grid via an external customer MV/LV AC transformer. Grid connection inverter with 230 V, L-N / 400Vac, L-L output is intended with and without AC transformer for Category A2 and A3 plant.
SolarEdge	SE40K	Grid-tied PV inverter	Bureau Veritas	2020/12/19	19TH0534-NRS 097-2-1 2	U20-1043	Yes	For both 230 V, L-N / 400Vac, L-L and 277 Vac L-N / 480 Vac L-L output, inverter may only be used in plants according to Category A3: 100 kVA - 1MVA and connection to the grid via an external customer MV/LV AC transformer.
SolarEdge	SE50K	Grid-tied PV inverter	Bureau Veritas	2021/06/07	20TH0532-NRS 097-2-1 0	U21-0499	Yes	Grid connection inverter for 230 V, L-N / 400Vac, L-L output only and is intended with and without AC transformer for Category A2 and A3 plant.
SolarEdge	SE55K	Grid-tied PV inverter	Bureau Veritas	2021/06/07	20TH0532-NRS 097-2-1 0	U21-0499	Yes	Grid connection inverter for 230 V, L-N / 400Vac, L-L output only and is intended with and without AC transformer for Category A2 and A3 plant.
SolarEdge	SE66.6K	Grid-tied PV inverter	Bureau Veritas	2021/06/07	20TH0532-NRS 097-2-1 0	U21-0499	Yes	Grid connection inverter for 230 V, L-N / 400Vac, L-L output only and is intended with and without AC transformer for Category A2 and A3 plant.
SolarEdge	SE82.8K	Grid-tied PV inverter	Bureau Veritas	2021/06/07	20TH0532-NRS 097-2-1 0	U21-0499	Yes	Grid connection inverter for 230 V, L-N / 400Vac, L-L output only and is intended with and without AC transformer for Category A2 and A3 plant.
SolarEdge	SE100K	Grid-tied PV inverter	Bureau Veritas	2021/06/07	20TH0532-NRS 097-2-1 0	U21-0499	Yes	Grid connection inverter for 230 V, L-N / 400Vac, L-L output only and is intended with and without AC transformer for Category A2 and A3 plant.
SolarEdge	SE66.6K*	Grid-tied PV inverter	Bureau Veritas	2021/06/07	20TH0532-NRS 097-2-1 0	U21-0499	Yes	Model with AC output voltage 277 Vac L-N / 480 Vac L-L, is intended for grid connection with an external customer MV/LV AC transformer and only for plants with Category A3: 100 kVA - 1MVA.
SolarEdge	SE80K*	Grid-tied PV inverter	Bureau Veritas	2021/06/07	20TH0532-NRS 097-2-1 0	U21-0499	Yes	For both 230 V, L-N / 400Vac, L-L and 277 Vac L-N / 480 Vac L-L output, inverter may only be used in plants according to Category A3: 100 kVA - 1MVA and connection to the grid via an external customer MV/LV AC transformer.
SolarEdge	SE120K*	Grid-tied PV inverter	Bureau Veritas	2021/06/07	20TH0532-NRS 097-2-1 0	U21-0499	Yes	For both 230 V, L-N / 400Vac, L-L and 277 Vac L-N / 480 Vac L-L output, inverter may only be used in plants according to Category A3: 100 kVA - 1MVA and connection to the grid via an external customer MV/LV AC transformer.
SolarEdge	SE75K	Grid-tied PV inverter	Bureau Veritas	2021/04/01	17TH0209-NRS 097-2-1 2	U21-0295	Yes	
SolarEdge	SE 2200H	Hybrid PV inverter grid-tied	Bureau Veritas	2022/01/26	16TH0371-NRS 097-2-1 1	U22-0010	Yes	
SolarEdge	SE 4000H	Hybrid PV inverter grid-tied	Bureau Veritas	2022/01/26	16TH0371-NRS 097-2-1 1	U22-0010	Yes	
SolarEdge	SE 5000H	Hybrid PV inverter grid-tied	Bureau Veritas	2022/01/26	16TH0371-NRS 097-2-1 1	U22-0010	Yes	
SolarEdge	SE 6000H	Hybrid PV inverter grid-tied	Bureau Veritas	2022/01/26	16TH0371-NRS 097-2-1 1	U22-0010	Yes	
SolarEdge	SE3K	Grid-tied PV inverter	TUV SUD	2021/09/03	713224660_000	D 082496 0022 Rev.00	Yes	
SolarEdge	SE4K	Grid-tied PV inverter	TUV SUD	2021/09/03	713224660_000	D 082496 0022 Rev.00	Yes	
SolarEdge	SE5K	Grid-tied PV inverter	TUV SUD	2021/09/03	713224660_000	D 082496 0022 Rev.00	Yes	
SolarEdge	SE6K	Grid-tied PV inverter	TUV SUD	2021/09/03	713224660_000	D 082496 0022 Rev.00	Yes	

SolarEdge	SE7K	Grid-tied PV inverter	TUV SUD	2021/09/03	713224680_000	D 082496 0022 Rev.00	Yes	
SolarEdge	SE8K	Grid-tied PV inverter	TUV SUD	2021/09/03	713224680_000	D 082496 0022 Rev.00	Yes	
SolarEdge	SE9K	Grid-tied PV inverter	TUV SUD	2021/09/03	713224680_000	D 082496 0022 Rev.00	Yes	
SolarEdge	SE10K	Grid-tied PV inverter	TUV SUD	2021/09/03	713224680_000	D 082496 0022 Rev.00	Yes	
SolarEdge	SE12.5K	Grid-tied PV inverter	TUV SUD	2021/09/03	713224680_000	D 082496 0022 Rev.00	Yes	
SolarEdge	SE15K	Grid-tied PV inverter	TUV SUD	2021/09/03	713224680_000	D 082496 0022 Rev.00	Yes	
SolarEdge	SE16K	Grid-tied PV inverter	TUV SUD	2021/09/03	713224680_000	D 082496 0022 Rev.00	Yes	
SolarEdge	SE17K	Grid-tied PV inverter	TUV SUD	2021/09/03	713224680_000	D 082496 0022 Rev.00	Yes	
SolaX Power	SK-TL 3000 E/E-S/C/C-S/R/R-S	Grid-tied PV inverter	TUV SUD	2018/03/29	70.409.18.010.02-00	D 18 03 85769 043	Yes	
SolaX Power	SK-TL 3700 E/C/R	Grid-tied PV inverter	TUV SUD	2018/03/29	70.409.18.010.02-00	D 18 03 85769 043	Yes	
SolaX Power	SK-TL 5000 E/C/R	Grid-tied PV inverter	TUV SUD	2018/03/29	70.409.18.010.02-00	D 18 03 85769 043	Yes	
SolaX Power	SK-SU3000 E/E-S/C/C-S	Grid-tied PV inverter	TUV SUD	2018/03/29	70.409.18.010.02-00	D 18 03 85769 043	Yes	
SolaX Power	SK-SU3700 E/C	Grid-tied PV inverter	TUV SUD	2018/03/29	70.409.18.010.02-00	D 18 03 85769 043	Yes	
SolaX Power	SK-SU5000 E/C	Grid-tied PV inverter	TUV SUD	2018/03/29	70.409.18.010.02-00	D 18 03 85769 043	Yes	
SolaX Power	X3-30.0-T-N	Grid-tied PV inverter	TUV SUD	2017/08/04	70.409.17.128.02-01	D 17 08 85769 026	Yes	
SolaX Power	X3-30.0-T-D	Grid-tied PV inverter	TUV SUD	2017/08/04	70.409.17.128.02-01	D 17 08 85769 026	Yes	
SolaX Power	X3-36.0-T-N	Grid-tied PV inverter	TUV SUD	2017/08/04	70.409.17.128.02-01	D 17 08 85769 026	Yes	
SolaX Power	X3-36.0-T-D	Grid-tied PV inverter	TUV SUD	2017/08/04	70.409.17.128.02-01	D 17 08 85769 026	Yes	
SolaX Power	X1-Hybrid-5.0-D-E	Hybrid PV inverter grid-tied	TUV SUD	2019/07/31	70.409.19.191.01-00	D 08576900055	Yes	
SolaX Power	X1-Hybrid-5.0-N-E	Hybrid PV inverter grid-tied	TUV SUD	2019/07/31	70.409.19.191.01-00	D 08576900055	Yes	
SolaX Power	X1-Hybrid-4.6-D-E	Hybrid PV inverter grid-tied	TUV SUD	2019/07/31	70.409.19.191.01-00	D 08576900055	Yes	
SolaX Power	X1-Hybrid-4.6-N-E	Hybrid PV inverter grid-tied	TUV SUD	2019/07/31	70.409.19.191.01-00	D 08576900055	Yes	
SolaX Power	X1-Hybrid-3.7-D-E	Hybrid PV inverter grid-tied	TUV SUD	2019/07/31	70.409.19.191.01-00	D 08576900055	Yes	
SolaX Power	X1-Hybrid-3.7-N-E	Hybrid PV inverter grid-tied	TUV SUD	2019/07/31	70.409.19.191.01-00	D 08576900055	Yes	
SolaX Power	X1-Hybrid-3.0-D-E	Hybrid PV inverter grid-tied	TUV SUD	2019/07/31	70.409.19.191.01-00	D 08576900055	Yes	
SolaX Power	X1-Hybrid-3.0-N-E	Hybrid PV inverter grid-tied	TUV SUD	2019/07/31	70.409.19.191.01-00	D 08576900055	Yes	
SolaX Power	X1-Hybrid-5.0-D-C	Hybrid PV inverter grid-tied	TUV SUD	2019/07/31	70.409.19.191.01-00	D 08576900055	Yes	
SolaX Power	X1-Hybrid-5.0-N-C	Hybrid PV inverter grid-tied	TUV SUD	2019/07/31	70.409.19.191.01-00	D 08576900055	Yes	
SolaX Power	X1-Hybrid-4.6-D-C	Hybrid PV inverter grid-tied	TUV SUD	2019/07/31	70.409.19.191.01-00	D 08576900055	Yes	
SolaX Power	X1-Hybrid-4.6-N-C	Hybrid PV inverter grid-tied	TUV SUD	2019/07/31	70.409.19.191.01-00	D 08576900055	Yes	
SolaX Power	X1-Hybrid-3.7-D-C	Hybrid PV inverter grid-tied	TUV SUD	2019/07/31	70.409.19.191.01-00	D 08576900055	Yes	
SolaX Power	X1-Hybrid-3.7-N-C	Hybrid PV inverter grid-tied	TUV SUD	2019/07/31	70.409.19.191.01-00	D 08576900055	Yes	
SolaX Power	X1-Hybrid-3.0-D-C	Hybrid PV inverter grid-tied	TUV SUD	2019/07/31	70.409.19.191.01-00	D 08576900055	Yes	
SolaX Power	X1-Hybrid-3.0-N-C	Hybrid PV inverter grid-tied	TUV SUD	2019/07/31	70.409.19.191.01-00	D 08576900055	Yes	
SolaX Power	X1-Hybrid-5.0-D-I	Hybrid PV inverter grid-tied	TUV SUD	2019/07/31	70.409.19.191.01-00	D 08576900055	Yes	
SolaX Power	X1-Hybrid-5.0-N-I	Hybrid PV inverter grid-tied	TUV SUD	2019/07/31	70.409.19.191.01-00	D 08576900055	Yes	

Solplanet	ASW50K-LT-G2	Grid-tied PV inverter	TÜV SÜD	2022/07/25	70.409.22.286.25-00	D 099567 0067 Rev.00		Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Solplanet	ASW40K-LT-G2 Pro	Grid-tied PV inverter	TÜV SÜD	2022/07/25	70.409.22.286.25-00	D 099567 0067 Rev.00		Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Solplanet	ASW45K-LT-G2 Pro	Grid-tied PV inverter	TÜV SÜD	2022/07/25	70.409.22.286.25-00	D 099567 0067 Rev.00		Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Solplanet	ASW50K-LT-G2 Pro	Grid-tied PV inverter	TÜV SÜD	2022/07/25	70.409.22.286.25-00	D 099567 0067 Rev.00		Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Soltaro	SOL-10KW-3P	Hybrid PV inverter grid-tied	TÜV SÜD	2019/07/26	6429018047301A	D 104877 0003		Yes	
Sungrow	SH5K-20	Hybrid PV inverter grid-tied	Dekra	2018/05/31	6025450 51	6025450 02AOC		Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Sungrow	SH5K-30	Hybrid PV inverter grid-tied	Dekra	2020/03/27	6072682 50	6072682 01AOC		Yes	
Sungrow	SG36KTL-M	Grid-tied PV inverter	TÜV SÜD	2018/03/26	704091708004-01	D180373342197		Yes	
Sungrow	SG60KTL	Grid-tied PV inverter	TÜV SÜD	2018/02/08	704091708005-01	D180173342198		Yes	
Sungrow	SG80KTL	Grid-tied PV inverter	Dekra	2018/07/11	6035428 50	6035428 01AOC		Yes	
Sungrow	SG80KTL-20	Grid-tied PV inverter	Dekra	2018/07/11	6035428 50	6035428 01AOC		Yes	
Sungrow	SG33CX	Grid-tied PV inverter	TÜV NORD & Shenzhen Balun	2020/03/19	TRSHV11090/19/01_R2	COCSHV11090/19-01_R1		Yes	
Sungrow	SG40CX	Grid-tied PV inverter	TÜV NORD & Shenzhen Balun	2020/03/19	TRSHV11090/19/01_R2	COCSHV11090/19-01_R1		Yes	
Sungrow	SG50CX	Grid-tied PV inverter	TÜV NORD & Shenzhen Balun	2020/03/19	TRSHV11090/19/01_R2	COCSHV11090/19-01_R1		Yes	
Sungrow	SG110CX	Grid-tied PV inverter	TÜV NORD & Shenzhen Balun	2020/03/19	TRSHV11090/19/02_R2	COCSHV11090/19-02_R1		Yes	
Sungrow	SH5.0RT	Hybrid PV inverter grid-tied	TÜV NORD & Shenzhen Balun	2020/07/24	TRSHV11090/19/03	COCSHV11090/19-04		Yes	
Sungrow	SH6.0RT	Hybrid PV inverter grid-tied	TÜV NORD & Shenzhen Balun	2020/07/24	TRSHV11090/19/03	COCSHV11090/19-04		Yes	
Sungrow	SH8.0RT	Hybrid PV inverter grid-tied	TÜV NORD & Shenzhen Balun	2020/07/24	TRSHV11090/19/03	COCSHV11090/19-04		Yes	
Sungrow	SH10RT	Hybrid PV inverter grid-tied	TÜV NORD & Shenzhen Balun	2020/07/24	TRSHV11090/19/03	COCSHV11090/19-04		Yes	
Sungrow	SC50HV	Battery based inverter grid-tied	TÜV SÜD	2021/08/09	704092103524-00	D 0733420345 Rev.00		Yes	
Sungrow	SC50HV-20	Battery based inverter grid-tied	TÜV SÜD	2021/08/09	704092103524-00	D 0733420345 Rev.00		Yes	
Sungrow	SH3.0RS	Hybrid PV inverter grid-tied	TÜV Rheinland	2022/03/15	CN22QHUI 001	AK 50536847 0001		Yes	
Sungrow	SH3.6RS	Hybrid PV inverter grid-tied	TÜV Rheinland	2022/03/15	CN22QHUI 001	AK 50536847 0001		Yes	
Sungrow	SH4.0RS	Hybrid PV inverter grid-tied	TÜV Rheinland	2022/03/15	CN22QHUI 001	AK 50536847 0001		Yes	
Sungrow	SH5.0RS	Hybrid PV inverter grid-tied	TÜV Rheinland	2022/03/15	CN22QHUI 001	AK 50536847 0001		Yes	
Sungrow	SH6.0RS	Hybrid PV inverter grid-tied	TÜV Rheinland	2022/03/15	CN22QHUI 001	AK 50536847 0001		Yes	
Sungrow	SG75CX-P2	Grid-tied PV inverter	TÜV Rheinland	2022/03/16	CN224TCO 001	AK 50536779 0001		Yes	
Sungrow	SG100CX-P2	Grid-tied PV inverter	TÜV Rheinland	2022/03/16	CN224TCO 001	AK 50536779 0001		Yes	
Sungrow	SG125CX-P2	Grid-tied PV inverter	TÜV Rheinland	2022/03/16	CN224TCO 001	AK 50536779 0001		Yes	
Sunpro	SP3KL1	Hybrid PV inverter grid-tied	TÜV SÜD	2022/08/16	64.290.22.30154.01	D 107931 0034 Rev.00		Yes	
Sunpro	SP3KL1	Hybrid PV inverter grid-tied	TÜV SÜD	2022/08/16	64.290.22.30154.01	D 107931 0034 Rev.00		Yes	
Sunpro	SP4KL1	Hybrid PV inverter grid-tied	TÜV SÜD	2022/08/16	64.290.22.30154.01	D 107931 0034 Rev.00		Yes	
Sunpro	SP4KL1	Hybrid PV inverter grid-tied	TÜV SÜD	2022/08/16	64.290.22.30154.01	D 107931 0034 Rev.00		Yes	
Sunpro	SP5KL1	Hybrid PV inverter grid-tied	TÜV SÜD	2022/08/16	64.290.22.30154.01	D 107931 0034 Rev.00		Yes	
Sunpro	SP6KL1	Hybrid PV inverter grid-tied	TÜV SÜD	2022/08/16	64.290.22.30154.01	D 107931 0034 Rev.00		Yes	
Sunsynk	Sunsynk-8K-SG01LP1	Hybrid PV inverter grid-tied	Dongguan Balun	2022/03/30	BL-DG2220307-B01	BL-DG2220307D03		Yes	
Sunsynk	Sunsynk-7.6K-SG01LP1	Hybrid PV inverter grid-tied	Dongguan Balun	2022/03/30	BL-DG2220307-B01	BL-DG2220307D03		Yes	
Sunsynk	Sunsynk-6K-SG01LP1	Hybrid PV inverter grid-tied	Dongguan Balun	2022/03/30	BL-DG2220307-B01	BL-DG2220307D03		Yes	
Sunsynk	Sunsynk-5K-SG01LP1	Hybrid PV inverter grid-tied	Dongguan Balun	2022/03/30	BL-DG2220307-B01	BL-DG2220307D03		Yes	
Sunsynk	Sunsynk-3.6K-SG01LP1	Hybrid PV inverter grid-tied	Dongguan Balun	2022/03/30	BL-DG2220307-B01	BL-DG2220307D03		Yes	
Sunsynk	Sunsynk-8K-SG02LP1	Hybrid PV inverter grid-tied	Dongguan Balun	2022/03/30	BL-DG2220307-B01	BL-DG2220307D03		Yes	
Sunsynk	Synk-7.6K-SG02LP1	Hybrid PV inverter grid-tied	Dongguan Balun	2022/03/30	BL-DG2220307-B01	BL-DG2220307D03		Yes	
Sunsynk	Synk-6K-SG02LP1	Hybrid PV inverter grid-tied	Dongguan Balun	2022/03/30	BL-DG2220307-B01	BL-DG2220307D03		Yes	
Sunsynk	Synk-5K-SG02LP1	Hybrid PV inverter grid-tied	Dongguan Balun	2022/03/30	BL-DG2220307-B01	BL-DG2220307D03		Yes	
Sunsynk	Synk-3.6K-SG02LP1	Hybrid PV inverter grid-tied	Dongguan Balun	2022/03/30	BL-DG2220307-B01	BL-DG2220307D03		Yes	
Sunsynk	Synk-8K-SG02LP1-B	Hybrid PV inverter grid-tied	Dongguan Balun	2022/03/30	BL-DG2220307-B01	BL-DG2220307D03		Yes	
Sunsynk	Synk-7.6K-SG02LP1-B	Hybrid PV inverter grid-tied	Dongguan Balun	2022/03/30	BL-DG2220307-B01	BL-DG2220307D03		Yes	
Sunsynk	Synk-6K-SG02LP1-B	Hybrid PV inverter grid-tied	Dongguan Balun	2022/03/30	BL-DG2220307-B01	BL-DG2220307D03		Yes	
Sunsynk	Synk-5K-SG02LP1-B	Hybrid PV inverter grid-tied	Dongguan Balun	2022/03/30	BL-DG2220307-B01	BL-DG2220307D03		Yes	
Sunsynk	Synk-3.6K-SG02LP1-B	Hybrid PV inverter grid-tied	Dongguan Balun	2022/03/30	BL-DG2220307-B01	BL-DG2220307D03		Yes	
Sunsynk	Synk-12K-SG01LP1	Hybrid PV inverter grid-tied	TÜV Rheinland	2022/05/31	CN22MMSO 002	AK 50546025 0001		Yes	
Sunsynk	Synk-14K-SG01LP1	Hybrid PV inverter grid-tied	TÜV Rheinland	2022/05/31	CN22MMSO 002	AK 50546025 0001		Yes	
Sunsynk	Synk-16K-SG01LP1	Hybrid PV inverter grid-tied	TÜV Rheinland	2022/05/31	CN22MMSO 002	AK 50546025 0001		Yes	
Sunsynk	SYNK-6K-SG04LP3	Hybrid PV inverter grid-tied	TÜV NORD & Shenzhen Balun	2021/06/10	BL-DG2160287-B01	BL-DG2160288D01		Yes	
Sunsynk	SYNK-8K-SG04LP3	Hybrid PV inverter grid-tied	TÜV NORD & Shenzhen Balun	2021/06/10	BL-DG2160287-B01	BL-DG2160288D01		Yes	
Sunsynk	SYNK-10K-SG04LP3	Hybrid PV inverter grid-tied	TÜV NORD & Shenzhen Balun	2021/06/10	BL-DG2160287-B01	BL-DG2160288D01		Yes	
Sunsynk	SYNK-12K-SG04LP3	Hybrid PV inverter grid-tied	TÜV NORD & Shenzhen Balun	2021/06/10	BL-DG2160287-B01	BL-DG2160288D01		Yes	
Sunsynk	SUNSYNK-29.9K-SG01HP3-EU-BM3	Hybrid PV inverter grid-tied	TÜV Rheinland	2023/07/13	CN22G75A 004	AK 50594013 0001		Yes	
Sunsynk	SUNSYNK-30K-SG01HP3-EU-BM3	Hybrid PV inverter grid-tied	TÜV Rheinland	2023/07/13	CN22G75A 004	AK 50594013 0001		Yes	
Sunsynk	SUNSYNK-35K-SG01HP3-EU-BM3	Hybrid PV inverter grid-tied	TÜV Rheinland	2023/07/13	CN22G75A 004	AK 50594013 0001		Yes	
Sunsynk	SUNSYNK-40K-SG01HP3-EU-BM4	Hybrid PV inverter grid-tied	TÜV Rheinland	2023/07/13	CN22G75A 004	AK 50594013 0001		Yes	
Sunsynk	SUNSYNK-50K-SG01HP3-EU-BM4	Hybrid PV inverter grid-tied	TÜV Rheinland	2023/07/13	CN22G75A 004	AK 50594013 0001		Yes	
Sunsynk	SYNK-3K-SG04LP1	Hybrid PV inverter grid-tied	TÜV Rheinland	2023/01/05	CN22MT63 002	AK 50570087 0001		Yes	
Sunsynk	SYNK-3K-SG04LP1-24	Hybrid PV inverter grid-tied	TÜV Rheinland	2023/01/05	CN22MT63 002	AK 50570087 0001		Yes	
Sunsynk	SYNK-3.6K-SG04LP1	Hybrid PV inverter grid-tied	TÜV Rheinland	2023/01/05	CN22MT63 002	AK 50570087 0001		Yes	
Sunsynk	SYNK-5K-SG04LP1	Hybrid PV inverter grid-tied	TÜV Rheinland	2023/01/05	CN22MT63 002	AK 50570087 0001		Yes	
Sunsynk	SYNK-6K-SG04LP1	Hybrid PV inverter grid-tied	TÜV Rheinland	2023/01/05	CN22MT63 002	AK 50570087 0001		Yes	
Sunways	STH-4KTL-HT	Hybrid PV inverter grid-tied	TÜV SÜD	2021/01/14	704092001222-00	D 104339 0044 Rev. 00		Yes	
Sunways	STH-5KTL-HT	Hybrid PV inverter grid-tied	TÜV SÜD	2021/01/14	704092001222-00	D 104339 0044 Rev. 00		Yes	
Sunways	STH-6KTL-HT	Hybrid PV inverter grid-tied	TÜV SÜD	2021/01/14	704092001222-00	D 104339 0044 Rev. 00		Yes	
Sunways	STH-8KTL-HT	Hybrid PV inverter grid-tied	TÜV SÜD	2021/01/14	704092001222-00	D 104339 0044 Rev. 00		Yes	
Sunways	STH-10KTL-HT	Hybrid PV inverter grid-tied	TÜV SÜD	2021/01/14	704092001222-00	D 104339 0044 Rev. 00		Yes	
Sunways	STH-12KTL-HT	Hybrid PV inverter grid-tied	TÜV SÜD	2021/01/14	704092001222-00	D 104339 0044 Rev. 00		Yes	
Sunways	STH-3KTL-HSS	Hybrid PV inverter grid-tied	TÜV SÜD	2021/12/08	704092101617-00	D 104339 0065 Rev.00		Yes	
Sunways	STH-3KTL-HS	Hybrid PV inverter grid-tied	TÜV SÜD	2021/12/08	704092101617-00	D 104339 0065 Rev.00		Yes	

Sunways	STH-3.6KTL-HSS	Hybrid PV inverter grid-tied	TUV SUD	2021/12/08		704092101617-00	D 104339 0065 Rev.00		Yes	
Sunways	STH-3.6KTL-HS	Hybrid PV inverter grid-tied	TUV SUD	2021/12/08		704092101617-00	D 104339 0065 Rev.00		Yes	
Sunways	STH-4.2KTL-HS	Hybrid PV inverter grid-tied	TUV SUD	2021/12/08		704092101617-00	D 104339 0065 Rev.00		Yes	
Sunways	STH-4.6KTL-HS	Hybrid PV inverter grid-tied	TUV SUD	2021/12/08		704092101617-00	D 104339 0065 Rev.00		Yes	
Sunways	STH-5KTL-HS	Hybrid PV inverter grid-tied	TUV SUD	2021/12/08		704092101617-00	D 104339 0065 Rev.00		Yes	
Sunways	STH-6KTL-HS	Hybrid PV inverter grid-tied	TUV SUD	2021/12/08		704092101617-00	D 104339 0065 Rev.00		Yes	
Sunways	STH-7KTL-HS	Hybrid PV inverter grid-tied	TUV SUD	2021/12/08		704092101617-00	D 104339 0065 Rev.00		Yes	
Sunways	STH-8KTL-HS	Hybrid PV inverter grid-tied	TUV SUD	2021/12/08		704092101617-00	D 104339 0065 Rev.00		Yes	
TBB Power	Apollo Matrix 3.0S	Hybrid PV inverter grid-tied	TUV NORD (Hangzhou)	2022/03/03		TRPVP12002/21B/01	COCPVP12002/21B-01		Yes	
TBB Power	Apollo Matrix 3.0M	Hybrid PV inverter grid-tied	TUV NORD (Hangzhou)	2022/03/03		TRPVP12002/21B/01	COCPVP12002/21B-01		Yes	
TBB Power	Apollo Matrix 5.0S	Hybrid PV inverter grid-tied	TUV NORD (Hangzhou)	2022/03/03		TRPVP12002/21B/01	COCPVP12002/21B-01		Yes	
TELE Haase Steuergerate	NA003	Network & system relay	Primara	2018/09/20		14PP035-12	18-315-00	Yes		Network and system grid protection voltage and frequency relay only and may only be used in conjunction with approved NRS 097-2-1 type tested inverters on this list.
Tesla	AC Powerwall 1092170-xx-y	Battery based inverter grid-tied	Intertek	2020/05/20		102591059CRT-051c	102591059CRT-051c	Yes		
Tesla	AC Powerwall 2012170-xx-y	Battery based inverter grid-tied	Intertek	2020/05/20		102591059CRT-051c	102591059CRT-051c	Yes		
Victron	MultiGrid 12/3000/120-50	Battery based inverter grid-tied	Primara	2017/11/20		16PP183-06 1	17-303-00	Yes		
Victron	MultiGrid 24/3000/70-50	Battery based inverter grid-tied	Primara	2017/11/20		16PP183-06 1	17-303-00	Yes		
Victron	MultiGrid 48/3000/35-50	Battery based inverter grid-tied	Primara	2017/11/20		16PP183-06 1	17-303-00	Yes		
Victron	MultiGrid - II 48/3000/35-32	Battery based inverter grid-tied	Primara	2018/10/02		17PP264-07 1	18-320-00	Yes		
Victron	MultiPlus - II 48/3000/35-32	Battery based inverter grid-tied	Kiwa Primara	2019/08/22		17PP264-07 3	18-320-01	Yes		
Victron	MultiPlus - II 48/3000/35-32GX	Battery based inverter grid-tied	Kiwa Primara	2019/08/22		17PP264-07 3	18-320-01	Yes		
Victron	MultiPlus - II 48/5000/70-50	Battery based inverter grid-tied	Kiwa Primara	2019/08/22		17PP264-07 3	18-320-01	Yes		
Voltronic	InfiniSolar 10k	Hybrid PV inverter grid-tied	Bureau Veritas	2020/10/30		PVZA180904N057-R1	2088AP0923N001001	Yes		
Ziehl	UFR1001E relay	Network & system relay	Bureau Veritas	2018/06/07		11TH0501-NRS 097-2-1 1	U18-0308	Yes		Network and system grid protection voltage and frequency relay only and may only be used in conjunction with approved NRS 097-2-1 type tested inverters on this list.

RCMU - residual current monitoring unit

RCD - residual current device

RCM - residual current monitoring

SPD - surge protection device

Notes:

1. The City shall not incur any liability of any nature whatsoever arising out of the publication by it of this list, or arising out of the selection by the user of a particular device. This includes liability for any losses incurred as a result of safety issues or negligence relating to the design, construction, installation, commissioning, operation and maintenance of any device listed on the list.
2. This list is for City purposes only and the use thereof as a guideline for the selection of a device is at the sole risk of the user.
3. The City does not guarantee the functionality or suitability of any device listed on the list.
4. Type testing certifications for inverters and ancillary equipment that must be added to the City's inverter list, shall be in accordance with latest NRS 097-2-1, currently NRS 097-2-1: 2017 Edition 2.1 (amended (2021-04-30)).
5. All grid-tied hybrid inverters shall be equipped with a separate suitably interlocked change-over switch if interlocked with the grid as specified in the Requirements for small scale embedded generation (SSEG) document.

<http://teamiles.capetown.gov.za/sites/esprotelmeas/SitePages/Home/.aspx/reference/PT Documents/voms/Approved inverter and equipment lto NRS 097-2-1>

2023-07-26